

FOR CARBON STEEL

CORRECTION FACTORS								
TEMP.°F	200	300	400	500	600	650	700	750
FACTOR	1.000	1.055	1.109	1.168	1.239	1.275	1.313	1.430

DIMENSION (mm)

		TRUNNION – NOMINAL PIPE SIZE																PAD TH'K MIN. "E"		DIM. "D" mm
		2"		3"		4"		6"		8"		10"		12"		14"				
		SCH. 80		SCH. 40 OR GREATER										3/8"W OR GREATER						
Y		80		110		140		190		240		290		340		380				
NOM. PIPE SIZE	PIPE SCH.	PAD REQUIREMENTS																PAD TH'K MIN. "E"	DIM. "D" mm	
		NO PAD	PAD	NO PAD	PAD	NO PAD	PAD	NO PAD	PAD	NO PAD	PAD	NO PAD	PAD	NO PAD	PAD	NO PAD	PAD			
		MOMENT CAPACITY OF ONE TRUNNION. (INCH–KIPS)																		
3"	40	1	6															5.5	40	
4"	40	1	7	3	15													6.0	50	
6"	40	2	8	4	17	6	28											7.0	65	
8"	40	2	9	5	19	8	32	17	69									8.5	90	
10"	40			6	21	9	35	20	77	34	130							9.0	100	
12"	3/8"W			5	21	9	34	19	74	33	125	51	195					9.5	100	
14"	3/8"W					9	33	19	71	31	120	49	186	69	262			9.5	115	
16"	3/8"W					8	30	17	66	29	112	46	174	64	245	78	295	9.5	115	
18"	3/8"W							16	62	28	106	43	164	61	231	73	278	9.5	125	
20"	3/8"W							16	59	26	100	41	156	57	219	69	264	9.5	125	
24"	3/8"W							14	54	24	91	37	142	52	200	63	241	9.5	140	
30"	3/8"W									21	82	33	127	47	179	57	215	9.5	165	
36"	3/8"W											30	116	43	163	52	197	9.5	180	
42"	3/8"W											28	107	40	151	48	182	9.5	190	
3"	80	3	9															5.5	40	
4"	80	3	10	7	21													6.0	50	
6"	80	5	11	10	26	17	43											7.0	65	
8"	80	5	11	12	26	20	49	43	106									8.5	90	
10"	1/2"W			11	26	18	48	38	104	65	175							9.0	100	
12"	1/2"W			10	26	16	45	35	97	59	164	92	255					9.5	100	
14"	1/2"W					15	43	33	93	57	157	88	244	124	343			9.5	115	
16"	1/2"W					14	40	31	87	53	147	82	228	116	321	140	387	9.5	115	
18"	1/2"W							30	82	50	138	78	215	109	302	132	365	9.5	125	
20"	1/2"W							28	77	47	131	74	204	104	287	125	346	9.5	125	
24"	1/2"W							26	71	43	120	67	186	95	262	114	316	9.5	140	
30"	1/2"W									39	107	60	167	85	234	102	283	9.5	165	
36"	1/2"W											55	152	77	214	93	258	9.5	180	
42"	1/2"W											51	141	72	198	86	239	9.5	190	

中威工程顧問股份有限公司 CHUNG WEI ENGINEERING CONSULTING CO., LTD.						DETAIL OF PIPE SUPPORT TYPE-61 (2 OF 3)						ENGINEERING STANDARD	
												HP6-DSD-A4-500-001	
BY	SHIH		CHK.	YANG								D-73	REV.
DATE	7/15/'24		APPR.	CHEN									1

FILE: D-73M.DWG