



DIMENSIONS (mm)					
LINE SIZE	A	B	C	PIPE CLAMP TYPE	D ⁽²⁾
1/2"	100	—	CUT FROM H200X100X5.5X8	PCL—A—1/2B	80
3/4"	100	—		PCL—A—3/4B	80
1"	100	—		PCL—A— 1B	80
1 1/2"	100	—		PCL—A—1 1/2B	80
2"	100	—		PCL—A— 2B	80
2 1/2"	100	—		PCL—A—2 1/2B	80
3"	100	—		PCL—A— 3B	180
4"	100	—		PCL—A— 4B	180
5"	100	—		PCL—A— 5B	180
6"	100	—		PCL—A— 6B	180
8"	100	—		PCL—A— 8B	180
10"	130	9		CUT FROM H200X200X8X12	PCL—A— 10B
12"	130	9	PCL—A— 12B		—
14"	130	9	PCL—A— 14B		—
16"	250	12	FAB. FROM 12 ^t PLATE	PCL—A— 16B	—
18"	250	12		PCL—A— 18B	—
20"	250	12		PCL—A— 20B	—
24"	300	12		PCL—A— 24B	—

DENOTE TYPE NO. _____

DENOTE LINE SIZE _____

_____ MODIFY LOPS=500 (IN mm) IF ANY

_____ MODIFY HOPS=130 (IN mm) IF ANY

_____ SEE NOTE 4

5. HOPS=HEIGHT OF PIPE SHOE, LOPS=LENGTH OF PIPE SHOE.

中威工程顧問股份有限公司 CHUNG WEI ENGINEERING CONSULTING CO., LTD. DETAIL OF PIPE SUPPORT TYPE-67 (1 OF 2)						ENGINEERING STANDARD	
						HP6-DSD-A4-500-001	
BY	SHIH		CHK.	YANG		D-81	REV. 1
DATE	7/15/'24		APPR.	CHEN			