



NOTES :

- 83-2B(P)-A(A)-130-500
- | | | | | | | |
|---------------------------|--|--|--|--|--|--------------------------------|
| DENOTE TYPE NO. | | | | | | MODIFY LOPS=500 (IN mm) IF ANY |
| DENOTE LINE SIZE | | | | | | MODIFY HOPS=130 (IN mm) IF ANY |
| DENOTE REIN. PAD IS REQ'D | | | | | | SEE SH'T D-80A TABLE "B" |
| | | | | | | SEE SH'T D-80A TABLE "A" |

2. THE MAX. LENGTH OF THIS MEMBER SHALL NOT EXCEED THE WIDTH OF BEAM.
3. PIPE SHOE LENGTH (SAY LOPS) TO SUIT BEAM WIDTH IN FIELD.
4. HOPS=HEIGHT OF PIPE SHOE, LOPS=LENGTH OF PIPE SHOE.

中威工程顧問股份有限公司 CHUNG WEI ENGINEERING CONSULTING CO., LTD. DETAIL OF PIPE SUPPORT TYPE-83 (1 OF 2) ENGINEERING STANDARD HP6-DSD-A4-500-001 D-101						REV. 1	
BY	SHIH		CHK.	YANG			
DATE	7/15/'24		APPR.	CHEN			