




NO.	7
PIECE	4
PIPE SIZE	(NOTE 4) STOP PIECE
26"	PLATE 16 TH'K
28"	
30"	
32"	
36"	
40"	
42"	

NOTES :

1. FOR DIMENSIONS AND INFORMATION NOT SHOWN ON THIS DWG., SEE SH'T D-81A.
2. DESIGNATION NUMBER DENOTE AS FOLLOWS :

86-30B-A-130-500

DENOTE TYPE NO. ————

DENOTE LINE SIZE ————

MODIFY LOPS=500 (IN mm) IF ANY

MODIFY HOPS=130 (IN mm) IF ANY

SEE NOTE 3

3. TYPE-A FOR INSULATION THICKNESS < 100
TYPE-B FOR INSULATION THICKNESS $> 100 < 150$
4. MATERIAL FOR STOP PIECES ACCORDING TO PIPE MATERIAL.
5. HOPS=HEIGHT OF PIPE SHOE, LOPS=LENGTH OF PIPE SHOE.

中威工程顧問股份有限公司 CHUNG WEI ENGINEERING CONSULTING CO., LTD. DETAIL OF PIPE SUPPORT TYPE-86 (2 OF 2)						ENGINEERING STANDARD	
						HP6-DSD-A4-500-001	
BY	SHIH		CHK.	YANG		D-108	REV. 1
DATE	7/15/'24		APPR.	CHEN			