


FOR LINE SIZE 2"-4"

ELEV.

LINE SIZE "A"	L (NOTE 5)
2"	106
3"	93
4"	106

NOTES :

1. FOR ALLOY STEEL, STAINLESS STEEL & STRESS RELIEF LINES, THE MATERIALS SHALL BE THE SAME AS MAIN LINES, AND IT SHALL BE FABRICATED TOGETHER WITH MAIN LINE IN SHOP.
2. THIS TYPE SHALL BE USED WITH M-42 TO DETERMINE THE LOWER COMPONENT TYPE. IN THIS DETAIL, USE TYPE-B, C H&R ONLY, AND NO NEED BASE PLATE UNDER MACHINE BOLT.

3. DESIGNATION NUMBER DENOTE AS FOLLOWS :

09-2B-05B

- └─┬─┐ DENOTE THE LOWER COMPONENT TYPE SEE M-42
- └─┬─┐ DENOTE DIMENSION "H" (IN 100mm)
- └─┬─┐ DENOTE SUPPORTED LINE SIZE "A"
- └─┬─┐ DENOTE TYPE NO.

4. DIMENSION "H" SHALL BE CUT TO SUIT IN FIELD .
5. DIMENSION "L" IS BASED ON LONG RADIUS ELBOW TO WHICH DUMMY PIPE IS WELDED.
6. ALL WELDED CONNECTIONS SHALL BE MADE WITH 6mm FILLET WELDS, BUT FOR ALL WELDS WITH PIPE, THE WELDING THICKNESS SHALL NOT EXCEED THE THICKNESS OF PIPE UNLESS OTHERWISE NOTED.



中鼎工程股份有限公司
CTCI CORPORATION

DETAIL OF PIPE SUPPORT

TYPE-09

ENGINEERING STANDARD

D7TS-701-E

D-9

REV.
1

BY
DATE

CHK.
APPR.