


FOR LINE SIZE 26"-42"



NOTES :

- FOR DIMENSIONS AND INFORMATION NOT SHOWN ON THIS DWG. SEE SH'T D-81A.
- DESIGNATION NUMBER DENOTE AS FOLLOWS :

55-30B-A-130-500

DENOTE TYPE NO.		MODIFY LOPS=500 (IN mm) IF ANY
DENOTE LINE SIZE		MODIFY HOPS=130 (IN mm) IF ANY
		SEE NOTE 3

- TYPE-A FOR INSULATION THICKNESS ≤ 100
 TYPE-B FOR INSULATION THICKNESS > 100 AND ≤ 150
 TYPE-C FOR INSULATION THICKNESS > 150 OR SPECIAL USED
- NON-ASBESTOS GASKET IS USED FOR ALLOY STEEL AND STAINLESS STEEL LINES.
 (MAX. LINE TEMP: 371°C)
- HOPS=HEIGHT OF PIPE SHOE, LOPS=LENGTH OF PIPE SHOE.



中鼎工程股份有限公司
CTCI CORPORATION

DETAIL OF PIPE SUPPORT

TYPE-55

(2 OF 2)

ENGINEERING STANDARD

D7TS-701-E

D-66A

REV.
1

BY		CHK.			
DATE		APPR.			