

FOR CARBON STEEL

CORRECTION FACTORS								
TEMP. °F	200	300	400	500	600	650	700	750
FACTOR	1.000	1.055	1.109	1.168	1.239	1.275	1.313	1.430

DIMENSION (mm)

		TRUNNION – NOMINAL PIPE SIZE																	
		2"		3"		4"		6"		8"		10"		12"		14"			
		SCH. 80		SCH. 40 OR GREATER										3/8"W OR GREATER					
Y		80		110		140		190		240		290		340		380			
NOM. PIPE SIZE	PIPE SCH.	PAD REQUIREMENTS																PAD TH'K MIN. "E"	DIM. "D" mm
		NO PAD		NO PAD		NO PAD		NO PAD		NO PAD		NO PAD		NO PAD		NO PAD			
		MOMENT CAPACITY OF ONE TRUNNION. (INCH–KIPS)																	
3"	40	1	6															5.5	40
4"	40	1	7	3	15													6.0	50
6"	40	2	8	4	17	6	28											7.0	65
8"	40	2	9	5	19	8	32	17	69									8.5	90
10"	40			6	21	9	35	20	77	34	130							9.0	100
12"	3/8"W			5	21	9	34	19	74	33	125	51	195					9.5	100
14"	3/8"W					9	33	19	71	31	120	49	186	69	262			9.5	115
16"	3/8"W					8	30	17	66	29	112	46	174	64	245	78	295	9.5	115
18"	3/8"W							16	62	28	106	43	164	61	231	73	278	9.5	125
20"	3/8"W							16	59	26	100	41	156	57	219	69	264	9.5	125
24"	3/8"W							14	54	24	91	37	142	52	200	63	241	9.5	140
30"	3/8"W									21	82	33	127	47	179	57	215	9.5	165
36"	3/8"W											30	116	43	163	52	197	9.5	180
42"	3/8"W											28	107	40	151	48	182	9.5	190
3"	80	3	9															5.5	40
4"	80	3	10	7	21													6.0	50
6"	80	5	11	10	26	17	43											7.0	65
8"	80	5	11	12	26	20	49	43	106									8.5	90
10"	1/2"W			11	26	18	48	38	104	65	175							9.0	100
12"	1/2"W			10	26	16	45	35	97	59	164	92	255					9.5	100
14"	1/2"W					15	43	33	93	57	157	88	244	124	343			9.5	115
16"	1/2"W					14	40	31	87	53	147	82	228	116	321	140	387	9.5	115
18"	1/2"W							30	82	50	138	78	215	109	302	132	365	9.5	125
20"	1/2"W							28	77	47	131	74	204	104	287	125	346	9.5	125
24"	1/2"W							26	71	43	120	67	186	95	262	114	316	9.5	140
30"	1/2"W									39	107	60	167	85	234	102	283	9.5	165
36"	1/2"W											55	152	77	214	93	258	9.5	180
42"	1/2"W											51	141	72	198	86	239	9.5	190



中鼎工程股份有限公司

CTCI CORPORATION

DETAIL OF PIPE SUPPORT

TYPE-61

(2 OF 3)

ENGINEERING STANDARD

D7TS-701-E

D-73

REV.
1

BY

CHK.

DATE

APPR.