

ALLEGHENY MILLWORK

RESPIRABLE CRYSTALLINE SILICA PROGRAM

Division 06 – Interior Finish Carpentry & Architectural Millwork
Field/Jobsite Installation

Compliant with 29 CFR 1926.1153
OSHA Respirable Crystalline Silica Standard for Construction

Project Name	
General Contractor	
Effective Date	

RESPIRABLE CRYSTALLINE SILICA PROGRAM

TABLE OF CONTENTS

Purpose.....	4
Scope	5
Field/Jobsite Installation Covered.....	5
Bystander & Multi-Employer Exposures.....	5
Out of Scope.....	5
Responsibilities	6
Safety Manager/Program Administrator	6
Project Managers	6
Superintendent/Competent Person.....	7
Installers & Field Personnel.....	7
Definitions	8
Specified Exposure Control Methods (OSHA Table 1)	10
Field Installation: Applicable Table 1 Tasks	11
Supplemental Requirements When Implementing Table 1	13
Alternative Exposure Control Methods	14
Performance Option.....	14
Scheduled Monitoring Option	14
Sample Collection & Analysis	14
Employee Notification	15
Observation & Monitoring.....	15
Hierarchy of Controls.....	15
Field Installation Control Methods	16
Engineering Controls: Jobsite	16
Work Practices	16
Multi-Employer Jobsite Coordination.....	17
Respiratory Protection	17
Jobsite Housekeeping	18
Written Exposure Control Plan (ECP).....	19
Medical Surveillance.....	20
Initial (Baseline) Examination	20
Periodic Examinations	20
Information Provided to the PLHCP	20
Written Medical Report (to Employee)	21
Written Medical Opinion (to Allegheny Millwork).....	21
Specialist Examination	21

Hazard Communication & Training	7
Recordkeeping	7
Exposure Monitoring Records	7
Objective Data Records	7
Medical Surveillance Records	7
Training Records	7
Program Evaluation	7
Project Specific Exposure Control Plan (ECP)	Appendix A

PURPOSE

This Respirable Crystalline Silica Program has been developed by Allegheny Millwork to prevent employee exposure to hazardous levels of Respirable Crystalline Silica (RCS) arising from Division 06 — Interior Finish Carpentry and Architectural Millwork field installation activities performed at construction jobsites. This program is intended to meet the requirements of the OSHA Respirable Crystalline Silica Standard for Construction, 29 CFR 1926.1153.

This program applies exclusively to installation at the project jobsite. Shop fabrication activities performed at Allegheny Millwork facilities are governed by a separate silica program under the OSHA General Industry standard (29 CFR 1910.1053) and are outside the scope of this document.

Chronic exposure to Respirable Crystalline Silica can result in silicosis, lung cancer, chronic obstructive pulmonary disease (COPD), and kidney disease. While interior finish carpentry and architectural millwork installation is not traditionally associated with heavy silica exposure, field work regularly involves cutting, drilling, grinding, and site-finishing of materials that contain crystalline silica, including:

- Prefabricated engineered stone, quartz-composite, and natural stone countertops and vanity tops delivered to the jobsite for final fit, seaming, and installation
- Solid-surface panels and countertops that require on-site scribing, seaming, or blending (some products contain silica fillers)
- Fiber-cement panels, trim, and soffit materials cut on site to fit architectural openings
- Cement-based tile backer board integrated into millwork and casework assemblies on site
- Pre-cast decorative elements, cast stone, and architectural concrete trim set or scribed on site
- Concrete, masonry, brick, and stone substrates drilled or anchored into during installation of cabinetry, paneling, wall systems, wainscoting, stair parts, handrails, and architectural woodwork
- Field patching, seam compounds, and cured fillers that may contain crystalline silica

This program establishes the controls, work practices, training, and documentation required to reduce jobsite exposure to Respirable Crystalline Silica to the lowest feasible level during Allegheny Millwork field installation activities.

SCOPE

This program applies to all Allegheny Millwork employees performing project jobsite installation; including superintendents, project managers, subcontractors and installers, who may be exposed to Respirable Crystalline Silica during any Division 06 Interior Finish Carpentry or Architectural Millwork installation activity covered by 29 CFR 1926.1153.

The OSHA standard applies to all occupational exposures to Respirable Crystalline Silica in construction work, except where employee exposure will remain below twenty-five (25) micrograms of Respirable Crystalline Silica per cubic meter of air ($25 \mu\text{g}/\text{m}^3$) as an 8-hour time-weighted average (TWA) under any foreseeable conditions.

FIELD/JOBSITE INSTALLATION COVERED

- On-site cutting, trimming, or scribing of prefabricated engineered stone, natural stone, solid-surface, or fiber-cement panels and countertops to fit as-built field conditions
- On-site drilling of concrete, CMU, brick, or stone substrates for mechanical anchoring of cabinetry, paneling, wall systems, wainscoting, stair parts, handrails, and architectural woodwork
- On-site seaming, edge-polishing, blending, or finishing of installed stone or solid-surface work
- On-site cutting or drilling of cement backer board when integrated into millwork assemblies at the point of installation
- Selective demolition or removal of existing silica-containing architectural elements (stone thresholds, cast trim, concrete sills, etc.) performed by Allegheny Millwork personnel prior to installation of new millwork
- Cleanup, housekeeping, and disposal of silica-containing debris, slurry, or dust generated by any of the above activities

BYSTANDER & MULTI-EMPLOYER EXPOSURES

Allegheny Millwork employees, subcontractors and installers frequently work in active construction environments where other trades may generate respirable silica dust, including concrete cutting, core drilling, masonry work, tile cutting, drywall sanding and demolition. This program addresses bystander exposure through coordination with the General Contractor, area restrictions, work sequencing and supplemental respiratory protection when necessary.

OUT OF SCOPE

- Shop fabrication activities performed at Allegheny Millwork facilities (covered by a separate program under 29 CFR 1910.1053)
- Transportation of materials between the shop and the jobsite (covered by general workplace programs)
- Silica exposures generated solely by other employers' operations, except to the extent Allegheny Millwork employees could be exposed as bystanders (see above section: "Bystander & Multi-Employee Exposures")

RESPONSIBILITIES

Protecting the health and safety of Allegheny Millwork employees is a shared responsibility. Upper Management provides the resources and authority necessary to implement this program, all other levels of the organization carry out the program as described below.

SAFETY MANAGER/PROGRAM ADMINISTRATOR

- Maintain this written Respirable Crystalline Silica Program and review it at least annually, or sooner if field operations, installation materials, tools or regulations change.
- Oversee jobsite assessments to identify silica containing materials involved in each installation project and determine whether exposures may exceed 25 $\mu\text{g}/\text{m}^3$ as an 8-hour TWA under any foreseeable conditions.
- Select and document appropriate control measures for each covered field task, using OSHA Table 1 specified exposure controls where available or the alternate exposure control methods (Performance Option or Scheduled Monitoring) where Table 1 does not apply or cannot be fully implemented.
- Develop a project-specific written Exposure Control Plan (ECP) where jobsite exposure is expected at or above the Action Level, using the template in Appendix A.
- Ensure jobsite tools, engineering controls (water delivery systems, dust shrouds, HEPA vacuums), PPE, and respirators required for field installation are procured and available to installers.
- Coordinate medical surveillance for installers required to use a respirator for 30 or more days per year due to RCS exposure, and maintain all medical records under lock and key.
- Maintain training records, exposure monitoring data, objective-data records, respirator medical clearances, and fit-test records in accordance with the Recordkeeping section.
- Coordinate with General Contractors, Controlling Contractors, other trades, and Host Employers to control multi-employer silica exposures at jobsites.
- Ensure all applicable elements of this program are implemented on every installation project and designate a qualified Competent Person for each project where RCS exposure is reasonably foreseeable.

PROJECT MANAGERS

- Incorporate silica controls, including project-specific ECPs, into pre-installation planning, submittals, subcontractor coordination, and site-specific safety plans.
- Verify that installers assigned to covered tasks have received the required Hazard Communication and silica-specific training, are medically cleared to wear respirators when required, and have been fit-tested in accordance with the company's Respiratory Protection Program.
- Coordinate with the General Contractor to schedule and sequence Allegheny Millwork installation work to avoid overlap with other trades generating silica dust whenever reasonably practicable.
- Review jobsite conditions, including the presence of concrete, masonry, or other silica-containing substrates, before installation crews mobilize, and request information about other trades' silica activities from the General Contractor.

SUPERINTENDENT/COMPETENT PERSON

- Make frequent and regular inspections of the jobsite, installation materials, tools, and equipment to confirm this program and the project ECP are being implemented.
- Identify existing and foreseeable Respirable Crystalline Silica hazards at the jobsite, and take prompt corrective action, including stopping work, to eliminate or minimize them.
- Verify that water supplies, dust shrouds, HEPA vacuums, and filters are functioning properly at the start of each shift and throughout silica-generating tasks.
- Monitor work by other trades in the immediate installation area for silica-generating activity; relocate Allegheny Millwork crews, request that adjacent work be stopped or rescheduled, or require supplemental respiratory protection as warranted.
- Ensure required respirators are worn, worn correctly, and stored properly in the jobsite trailer or vehicle.
- Report deficiencies, exposure incidents, and near-miss events to the Project Manager and Safety Department.

INSTALLERS & FIELD PERSONNEL

- Follow the work practices and engineering controls specified in OSHA Table 1 (or the alternative controls selected in the project ECP) for every covered installation task.
- Use assigned PPE and respirators correctly, keep them clean and in good condition, and report any damage or malfunction immediately.
- Participate in required training, exposure monitoring, respirator fit-testing, and the medical surveillance program.
- Report unsafe conditions, dust-control failures, suspected overexposures, or silica-generating activity by adjacent trades to the Superintendent/Competent Person.
- Report any signs or symptoms of silica-related illness, such as persistent cough, shortness of breath, or chest tightness, to the Superintendent/Competent Person.

DEFINITIONS

Unless otherwise noted, the definitions in the section are consistent with 29 CFR 1926.1153. If a term is not defined here, employees should contact the Superintendent, Competent Person or Safety Manager.

Term	Definition
Action Level	An airborne concentration of Respirable Crystalline Silica of 25 $\mu\text{g}/\text{m}^3$, calculated as an 8-Hour TWA.
Competent Person	An individual capable of identifying existing and foreseeable Respirable Crystalline Silica hazards in the workplace and authorized to take prompt corrective measures to eliminate or minimize them.
Employee Exposure	The exposure to airborne Respirable Crystalline Silica that would occur if the employees were not using respirators.
Engineered Stone	A manufactured composite material, commonly used for countertops, vanities and architectural surfaces, typically composed of 85% or more crushed quartz bound in a polymer resin. Engineered stone presents one the highest silica-exposure risks during filed finishing operations and requires strict adherence to wet-cutting, local exhaust ventilation and respiratory protection controls.
General Contractor	The employer that has overall responsibility for the construction project. On multi-employer jobsites, Allegheny Millwork will coordinate silica controls with the General Contractor.
HEPA Filter	A high-efficiency particulate air filter that is at least 99.97% efficient at removing monodispersed particles of 0.3 micrometers in diameter.
Objective Data	Information (such as air monitoring data from industry-wide surveys or calculations based on the composition of a substance) demonstrating employee exposure to Respirable Crystalline Silica associated with a particular product, material, task or activity. The data must reflect workplace conditions closely resembling, or with higher exposure potential than, current operations.
Permissible Exposure Limit (PEL)	50 $\mu\text{g}/\text{m}^3$ of Respirable Crystalline Silica, calculated as an 8-Hour TWA. Allegheny Millwork will ensure that no employee is exposed above this level.

Term	Definition
Physician or Other Licensed Healthcare Professional (PLHCP)	An individual whose legally permitted scope of practice (license, registration or certification_ allows him or her to independently provide or delegate responsibility for healthcare services required by the Medical Surveillance section of 29 CFR 1926.1153.
Respirable Crystalline Silica (RCS)	Quartz, cristobalite and/or tridymite contained in airborne particles that are determined to be respirable by a sampling device designated to meet the characteristics of respirable particle size selective samplers specified in ISO 7708:1995 (Air Quality – Particle Size Fraction Definitions for Health-Related Sampling)
Specialist	An American Board-Certified Specialist in Pulmonary Disease or an American Board-Certified Specialist in Occupational Medicine.

SPECIFIED EXPOSURE CONTROL METHODS (OSHA TABLE 1)

Wherever a Division 06 field installation task appears on OSHA Table 1, Allegheny Millwork will fully and properly implement the engineering controls, work practices, and respiratory protection specified for that task — unless exposures have been assessed and controlled under the Alternative Exposure Control Methods described in Section 6.0.

The table below is a field-installation-focused subset of OSHA Table 1 at 29 CFR 1926.1153(c). Tasks not applicable to Division 06 jobsite installation (for example, stationary masonry saws, jackhammers, walk-behind/drivable saws, drilling rigs, milling machines, crushing machines, and heavy excavation equipment) have been omitted. For any task not shown below, the Safety Department shall consult the full OSHA Table 1 before authorizing the work.

FIELD INSTALLATION: APPLICABLE TABLE 1 TASKS

#	Construction Task/Equipment	Engineering & Work Practice Control Methods	Respirator: ≤ 4 Hrs./Shift	Respirator: > 4 Hrs./Shift
2a	Handheld power saws (any blade diameter) used OUTDOORS: On-site trimming of fiber-cement trim, cement backerboard or stone panels during exterior facing millwork installation	• Use Saw equipped with integrated water delivery system that continuously feeds water to the blade. • Operate & maintain tool per manufacturer's instructions to minimize dust emissions.	None Required	N95 (or greater) filtering facepiece or half mask
2b	Handheld power saws (any blade diameter) used INDOORS or in an ENCLOSED AREA: On-site trimming or scribing countertops, cement-based panels, stone cladding or fiber-cement trim during interior millwork installation	• Use Saw equipped with integrated water delivery system that continuously feeds water to the blade. • Operate & maintain tool per manufacturer's instructions to minimize dust emissions.	N95 (or greater) filtering facepiece or half mask	N95 (or greater) filtering facepiece or half mask
3	Handheld power saws for cutting fiber-cement board (blade diameter ≤ 8 inches): OUTDOORS only (dust collection method)	• Use saw equipped with commercially available dust collection system. • Dust collector must provide manufacturer recommended airflow (or greater) and a filter with 99% efficiency. • Operate & maintain tool per manufacturer's instructions to minimize dust emissions.	None Required	None Required
7	Handheld & stand-mounted drills (including rotary hammer drills): used onsite to anchor cabinetry, wall panels, wainscoting, stair pairs or architectural millwork into concrete, CME, brick or stone substrates.	• Use drill equipped with commercially available shroud or cowl with dust collection system. • Dust collector must provide manufacturer recommended airflow (or greater) with a 99% efficient filter & a filter cleaning mechanism. • Use a HEPA filtered vacuum when cleaning holes • Operate & maintain tool per manufacturer's instructions to minimize dust emissions.	None Required	None Required

#	Construction Task/Equipment	Engineering & Work Practice Control Methods	Respirator: ≤ 4 Hrs./Shift	Respirator: > 4 Hrs./Shift
12a	Handheld grinders for uses other than mortar removal OUTDOORS only (wet method): onsite edge profiling of installed stone countertops or thresholds	• Use grinder equipped with integrated water delivery system that continuously feeds water to the grinding surface. • Operate & maintain tool per manufacturer's instructions to minimize dust emissions.	None Required	None Required
12b	Handheld grinders for uses OTHER than mortar removal – OUTDOORS (dust-collection method)	• Use grinder equipped with commercially available shroud or cowling with dust collection system. • Dust collector must provide ≥ 25 cfm airflow per inch of wheel diameter, a 99%+ efficient filter & a cyclonic pre-separator or filter cleaning mechanism. • Operate & maintain tool per manufacturer's instructions to minimize dust emissions.	None Required	None Required
12c	Handheld grinders for uses OTHER than mortar removal – INDOORS or ENCLOSED AREAS: Onsite seaming, edge polishing or blending of installed stone/solid surface countertops, grinding of cured patching or seam compounds.	• Use grinder equipped with commercially available shroud or cowling with dust collection system. • Dust collector must provide ≥ 25 cfm airflow per inch of wheel diameter, a 99%+ efficient filter & a cyclonic pre-separator or filter cleaning mechanism. • Operate & maintain tool per manufacturer's instructions to minimize dust emissions	None Required	None Required

SUPPLEMENTAL REQUIREMENTS WHEN IMPLEMENTING TABLE 1

When implementing the controls specified in the table above, Allegheny Millwork shall:

- For tasks performed indoors or in enclosed areas (including inside finished buildings, closets, small rooms or tented containment), coordinate with the General Contractor to provide a means of exhaust ventilation as needed to minimize the accumulation of visible airborne dust.
- For tasks using wet methods, apply water at flow rates sufficient to minimize the release of visible dust. Water-delivery systems and reservoirs must be inspected at the start of every shift and operating properly throughout the task.
- For tasks using dust collection, verify that the HEPA vacuum or dust extractor matches the tool manufacturer's airflow specification, that filters are clean and that hoses are unobstructed before work begins.
- Where an installer performs more than one Table 1 task during a shift and the combined duration exceeds four hours, the respiratory protection required for each task is the level specified for > 4 hours per shift. If the combined duration is four (4) hours or less, the respiratory protection required for each task is the level specified for ≤ 4 hours per shift.

ALTERNATIVE EXPOSURE CONTROL METHODS

Where a field installation task is not listed on OSHA Table 1, or where Allegheny Millwork cannot fully and properly implement the Table 1 controls for any reason, exposures will be assessed and controlled under this section.

Allegheny Millwork will assess the exposure of each employee who is or may reasonably be expected to be exposed to Respirable Crystalline Silica at or above the Action Level using either the Performance Option or the Scheduled Monitoring Option.

PERFORMANCE OPTION

Allegheny Millwork will assess the 8-hour TWA exposure for each employee based on any combination of air monitoring data or objective data sufficient to accurately characterize employee exposures to Respirable Crystalline Silica. Objective data may include industry-wide surveys, manufacturer exposure data for specific tool/material combinations, or historical Allegheny Millwork monitoring data for equivalent field installation operations.

SCHEDULED MONITORING OPTION

- Initial Monitoring: Allegheny Millwork will perform initial monitoring to assess the 8-hour TWA exposure for each employee, using one or more personal breathing-zone air samples that represent each shift, job classification, and work area. Where several installers perform the same task on the same shift in the same area, a representative sample may be taken from the employee(s) expected to have the highest exposure.
- If initial monitoring indicates exposure is below the Action Level, monitoring may be discontinued for the employees represented by those samples.
- If the most recent monitoring indicates exposure is at or above the Action Level but at or below the PEL, monitoring will be repeated within six (6) months.
- If the most recent monitoring indicates exposure is above the PEL, monitoring will be repeated within three (3) months.
- If monitoring indicates exposure is below the Action Level, monitoring will continue at six-month intervals until two consecutive measurements, taken at least seven days apart, are below the Action Level; at which point monitoring may be discontinued for the represented employees, unless reassessment is required.
- Reassessment: Allegheny Millwork will reassess exposures whenever a change in jobsite conditions, materials (e.g., transitioning from natural stone to engineered stone on a project), tools, engineering controls, personnel, or work practices may reasonably be expected to result in new or additional exposures at or above the Action Level.

SAMPLE COLLECTION & ANALYSIS

All Respirable Crystalline Silica samples will be collected by a qualified individual (e.g., a Certified Industrial Hygienist or qualified sampling technician working under CIH oversight) and analyzed by a laboratory accredited to ANSI/ISO/IEC 17025:2017 for the relevant crystalline silica analytical method, by a body compliant with ISO/IEC 17011 for implementation of quality assessment programs.

EMPLOYEE NOTIFICATION

Within five (5) working days after completing an exposure assessment, Allegheny Millwork will notify each affected employee in writing of the results or will post the results in a location accessible to all affected employees.

Whenever an exposure assessment indicates exposure is above the PEL, the written notification will describe the corrective action being taken to reduce exposure to or below the PEL.

OBSERVATION OF MONITORING

Where air monitoring is performed, affected employees or their designated representatives will be given the opportunity to observe. When observation requires entry into an area requiring protective clothing or equipment for any workplace hazard, Allegheny Millwork will provide the observer with such clothing and equipment at no cost and require its use.

HIERARCHY OF CONTROLS

Allegheny Millwork will use engineering and work-practice controls to reduce and maintain employee exposure to Respirable Crystalline Silica at or below the PEL, unless such controls are demonstrably not feasible. Where such controls are not sufficient to reduce exposure to or below the PEL, they will still be used to reduce exposure to the lowest feasible level and will be supplemented with respiratory protection.

FIELD INSTALLATION CONTROL METHODS

Allegheny Millwork will provide control methods that are either consistent with OSHA Table 1 or that otherwise minimize worker exposures to silica during field installation. These include engineering controls, work practices, administrative controls and respiratory protection tailored to the jobsite conditions.

ENGINEERING CONTROLS

- Handheld saws used on site for engineered stone, natural stone, fiber-cement, or cement backer shall be equipped with integrated water-feed systems (preferred for countertop finishing) or with OSHA-compliant dust shrouds connected to HEPA-filtered vacuums rated for the tool's required airflow.
- Rotary hammer drills and stand-mounted drills used to anchor millwork into concrete, CMU, brick, or stone shall use shroud-and-HEPA-vacuum dust collection, or integrated hollow-bit dust-extraction systems ("dustless drilling"). Dry drilling without dust control is prohibited in interior occupied or enclosed spaces.
- Handheld grinders used on site for seaming, edge-polishing, or blending of installed stone or solid-surface work shall use either integrated water delivery or commercially available shrouds connected to compliant dust collection.
- HEPA-filtered vacuums (not standard shop vacuums) shall be available on every Allegheny Millwork jobsite where covered tasks may be performed. Each installation vehicle or jobsite trailer shall carry at least one HEPA vacuum sized for the tools in use.
- Where feasible, silica-generating cuts shall be scheduled and performed at the shop under controlled conditions rather than in the field. Field cutting shall be limited to final fit, scribing, and unavoidable site adjustments.
- When a silica-generating task cannot be performed outdoors or in a ventilated area, Allegheny Millwork will establish a temporary containment (plastic sheeting barriers with negative air if required) in coordination with the Controlling Contractor.

WORK PRACTICES

- Pre-Task Planning: before starting any covered field task, the Superintendent/Competent Person shall confirm the correct tool/control combination is set up and operating, verify adjacent trades' activities, and brief the crew on silica controls for that task.
- Water supply and dust collection shall be verified at the start of the task and monitored throughout. Low water flow, a clogged filter, a torn shroud, or a disconnected hose is cause for stopping work immediately.
- Tools shall be operated and maintained per manufacturer instructions; worn blades, damaged shrouds, and clogged filters shall be replaced promptly. Spare consumables shall be stocked on each installation vehicle.
- Slurry, silica-laden water, and wet debris shall be contained and disposed of properly; they shall not be allowed to dry out on jobsite floors or tarps and re-aerosolize. Slurry shall not be poured down site drains.

- Work clothing contaminated with silica dust shall not be cleaned by shaking, blowing, or brushing. Disposable coveralls or a company-provided laundering option shall be available for installers whose clothing becomes visibly dusty.

MULTI-EMPLOYER JOBSITE COORDINATION

- Before mobilization, the Project Manager or Superintendent/Competent Person shall review the General Contractor's site-specific safety plan and any silica-related requirements imposed by the General Contractor.
- The Superintendent/Competent Person shall participate in jobsite pre-construction and weekly coordination meetings, raising silica concerns whenever Allegheny Millwork installation will overlap in space or time with concrete cutting, core drilling, masonry work, tile cutting, drywall finishing, or demolition.
- If other trades' silica-generating work cannot be rescheduled or isolated, Allegheny Millwork installers shall be relocated, work shall be suspended, or supplemental respiratory protection (minimum N95) shall be provided based on the Superintendent/Competent Person's assessment.
- Allegheny Millwork will inform the General Contractor of its own silica-generating activities so that other trades can be coordinated accordingly.

RESPIRATORY PROTECTION

Where respiratory protection is required by this program, whether specified by OSHA Table 1, required for tasks not listed in Table 1, or required because Table 1 controls cannot be fully implemented on site, Allegheny Millwork will provide each affected installer an appropriate respirator in compliance with the company's Respiratory Protection Program and 29 CFR 1910.134.

Specific jobsite situations requiring respiratory protection include:

- Where exposures exceed the PEL during the time needed to install or implement feasible engineering and work-practice controls.
- Where exposures exceed the PEL during tasks for which engineering and work-practice controls are not feasible in the jobsite environment.
- Tasks for which all feasible engineering and work-practice controls have been implemented but exposures still cannot be reduced to or below the PEL.
- Bystander exposure situations in which adjacent trades' silica-generating work cannot be avoided or isolated.

Installers required to wear respirators must be medically cleared, fit-tested, and trained in accordance with 29 CFR 1910.134. Fit testing shall be performed annually and whenever facial features change materially.

JOB SITE HOUSEKEEPING

- Dry sweeping or dry brushing is prohibited on Allegheny Millwork jobsites where such activity could contribute to employee exposure to Respirable Crystalline Silica, unless wet sweeping, HEPA-filtered vacuuming, or other equally effective methods are not feasible.
- The use of compressed air to clean clothing, tools, or work surfaces is prohibited where such activity could contribute to employee exposure, unless the compressed air is used with a ventilation system that effectively captures the dust cloud, or no alternative method is feasible.
- HEPA-filtered vacuums shall be used for routine cleanup of silica-containing dust in the installation area, in tool storage, and in vehicles used to transport tools and materials from the jobsite.
- Anchor-hole debris shall be HEPA-vacuumed before the hole is blown out, fastener set, or adhesive applied.

WRITTEN EXPOSURE CONTROL PLAN (ECP)

Where employee exposure on any installation project is expected to be at or above the Action Level, a written Exposure Control Plan (ECP) will be developed and implemented using the template in Appendix A.

The ECP will include, at a minimum:

- A description of the field tasks on the project that involve exposure to Respirable Crystalline Silica, including the specific materials and tools involved.
- A description of the engineering controls, work practices, and respiratory protection used to limit exposure for each task.
- A description of the jobsite housekeeping measures used to limit exposure.
- A description of the procedures used to restrict access to work areas — when necessary — to minimize the number of employees exposed, including exposures generated by other employers or sole proprietors on the multi-employer jobsite.
- Designation of the Superintendent/Competent Person responsible for frequent and regular inspections of the jobsite, materials, and equipment to ensure the ECP is implemented.

The written ECP will be reviewed at least annually or at the completion of the project, whichever is sooner, and updated as necessary. The ECP will be readily available for examination and copying, upon request, to each covered employee, their designated representatives, the Controlling Contractor, and OSHA.

MEDICAL SURVEILLANCE

Medical surveillance will be made available, at no cost and at a reasonable time and place, to each installer required to use a respirator for 30 or more days per year due to Respirable Crystalline Silica exposure during field installation work. Medical surveillance will be performed by a PLHCP.

INITIAL (BASELINE) EXAMINATION

An initial examination will be made available within 30 days of initial assignment, unless the employee has received a qualifying examination within the preceding three years. The initial examination shall include:

- A medical and work history, with emphasis on past, present, and anticipated exposure to Respirable Crystalline Silica, dust, and other agents affecting the respiratory system; any history of respiratory dysfunction (including shortness of breath, cough, or wheezing); history of tuberculosis; and smoking status and history.
- A physical examination with emphasis on the respiratory system.
- A chest X-ray (single postero-anterior radiographic projection at full inspiration on film [no less than 14 × 17 inches and no more than 16 × 17 inches] or digital radiography), interpreted and classified according to the International Labour Office (ILO) International Classification of Radiographs of Pneumoconioses by a NIOSH-certified B Reader.
- A pulmonary function test including FVC, FEV1, and FEV1/FVC ratio, administered by a spirometry technician holding a current certificate from a NIOSH-approved spirometry course.
- Testing for latent tuberculosis infection.
- Any other tests deemed appropriate by the PLHCP.

PERIODIC EXAMINATIONS

Examinations including all of the above (except latent tuberculosis testing) will be made available at least every three (3) years, or more frequently by the PLHCP.

INFORMATION PROVIDED TO THE PLHCP

Allegheny Millwork will provide the PLHCP with a copy of 29 CFR 1926.1153, a copy of this program, and:

- A description of the employee's former, current, and anticipated field installation duties as they relate to occupational exposure to Respirable Crystalline Silica.
- The employee's former, current, and anticipated exposure levels.
- A description of any PPE used or to be used by the employee, including duration of use.
- Information from records of prior employment-related medical examinations currently in Allegheny Millwork's control.

WRITTEN MEDICAL REPORT (TO EMPLOYEE)

Within 30 days of the examination, the PLHCP will provide the employee with a written medical report containing:

- The results of the examination, including any medical condition(s) that would place the employee at increased risk of material impairment from Respirable Crystalline Silica exposure, and any conditions requiring further evaluation or treatment.
- Any recommended limitations on the employee's use of respirators.
- Any recommended limitations on the employee's exposure to Respirable Crystalline Silica.
- A statement that the employee should be examined by a Specialist if the chest X-ray is classified as 1/0 or higher by the B Reader, or if referral is otherwise deemed appropriate.

WRITTEN MEDICAL OPINION (TO ALLEGHENY MILLWORK)

Within 30 days of the examination, Allegheny Millwork will obtain a written medical opinion from the PLHCP containing only:

- The date of the examination.
- A statement that the examination has met the requirements of 29 CFR 1926.1153.
- Any recommended limitations on the employee's use of respirators.

If the employee provides written authorization, the opinion may additionally include any recommended limitations on the employee's RCS exposure and/or a statement that the employee should be examined by a Specialist.

SPECIALIST EXAMINATION

If the PLHCP's written opinion indicates an employee should be examined by a Specialist, Allegheny Millwork will make the specialist examination available within 30 days of receiving the opinion. The Specialist will be provided the same information as the PLHCP, will provide a written report to the employee within 30 days, and will provide a written opinion to Allegheny Millwork within 30 days, with the same scope and employee-authorization rules as the PLHCP opinion.

HAZARD COMMUNICATION & TRAINING

Respirable Crystalline Silica is included in Allegheny Millwork's Hazard Communication Program established under 29 CFR 1910.1200. Installers have access to labels on containers of silica-containing materials and to the corresponding Safety Data Sheets (SDSs), which are maintained on each installation vehicle or jobsite trailer.

All field employees covered by this program shall be trained before initial field assignment, and at least annually thereafter or whenever installation operations change materially. Training shall cover:

- The health hazards associated with exposure to Respirable Crystalline Silica — including cancer, silicosis, COPD, kidney disease, and immune-system effects.
- Specific Division 06 field tasks that could result in RCS exposure (on-site cutting/seaming of stone countertops, cutting of fiber-cement trim, anchoring into concrete or masonry, site grinding and polishing, and demolition of existing silica-containing elements).
- Bystander exposure risks on multi-employer jobsites and how to recognize other trades' silica-generating activities.
- The specific measures Allegheny Millwork has implemented to protect installers — including Table 1 controls, engineering controls, work practices, housekeeping, and respirators.
- The contents of 29 CFR 1926.1153.
- The identity of the Competent Person(s) designated by Allegheny Millwork for each project.
- The purpose and contents of the company's Medical Surveillance Program and how to participate.

Each installer with potential exposure at or above the Action Level must be able to demonstrate knowledge and understanding of the items above. Training shall be documented, including date, topics, trainer, and attendees. A copy of 29 CFR 1926.1153 will be made available at no cost to any employee who requests it.

RECORDKEEPING

EXPOSURE MONITORING RECORDS

Allegheny Millwork will maintain an accurate record of all exposure measurements taken to assess employee exposure to Respirable Crystalline Silica during field installation work, including:

- The date of each sample.
- The task monitored and the project on which it was performed.
- The sampling and analytical methods used.
- The number, duration, and results of samples.
- The identity of the laboratory that performed the analysis.
- The type of PPE (including respirators) worn by the employees monitored.
- Name, social security number (or other unique identifier), and job classification of all employees represented by the monitoring, indicating which employees were actually monitored.

Exposure records will be maintained and made available in accordance with 29 CFR 1910.1020 and kept for at least thirty (30) years.

OBJECTIVE DATA RECORDS

Allegheny Millwork will maintain an accurate record of all objective data relied upon to comply with 29 CFR 1926.1053, including:

- The crystalline silica containing material in question.
- The source of the objective data.
- The testing protocol and results.
- A description of the field process, task or activity on which the data were based.
- Other data relevant to the process, task, activity, material or exposure on which the objective data were based.

Objective data records will be maintained in accordance with 29 CFR 1910.1020 and kept for at least thirty (30) years.

MEDICAL SURVEILLANCE RECORDS

Allegheny Millwork will maintain a medical surveillance record for each employee enrolled in medical surveillance under this program, including:

- Name and social security number (or other unique identifier).
- A copy of the PLHCP's and/or Specialist's written medical opinions.
- A copy of the information provided to the PLHCP and Specialist.

Medical records will be kept under lock and key, maintained in accordance with 29 CFR 1910.1020, and kept for at least the duration of employment plus thirty (30) years. Because silica-related diseases,

including lung cancer, may not appear for decades after exposure, these records are preserved for extended periods. If an employee works for Allegheny Millwork for less than one year, the medical records may be transferred to the employee upon separation in lieu of long-term retention.

TRAINING RECORDS

Training records, respirator medical-clearance records and fit-test records will be maintained by the Safety Department. Fit test records shall be retained until the next fit test is administered. Respirator medical clearances are kept under lock and key.

PROGRAM EVALUATION

This program will be reviewed and evaluated at least annually by the Safety Department. Review will also be triggered by any of the following:

- Material changes in Division 06 field installation operations, materials (e.g., new use of engineered stone or fiber-cement products on projects), tools, or engineering controls.
- Revisions to 29 CFR 1926.1153 or to other applicable OSHA standards (including 29 CFR 1910.134 Respiratory Protection, 29 CFR 1910.1200 Hazard Communication, and 29 CFR 1926.57 Ventilation).
- Exposure monitoring results indicating jobsite exposures at or above the Action Level or PEL.
- Employee reports of signs or symptoms consistent with silica-related illness.
- Jobsite inspections, near-miss reports, or enforcement findings suggesting the program is not adequately protecting installers.

The outcome of each review will be documented and retained with this program.