REQUEST FOR INFORMATION
RFI No. 007

Project: Harpeth Ridge Medical Office Building
Date Submitted: 08/06/2025
From: Marcus Oyelaran, Brightwater Builders, Inc.
To: Lindqvist Rowe Architects, PLLC
Discipline: Structural

Question:
Roof opening for RTU-3 is 6 inches smaller than the unit curb submitted. Please confirm framing revision.

Response (Lindqvist Rowe Architects, 08/13/2025):
Confirmed as drawn on the architectural sheets; structural governs where noted.

Evelyn Rowe, AIA