

REQUEST FOR INFORMATION

RFI No. 002

Project: Harpeth Ridge Medical Office Building

Date Submitted: 11/13/2024

From: Marcus Oyelaran, Brightwater Builders, Inc.

To: Lindqvist Rowe Architects, PLLC

Discipline: Electrical

Question:

Panel LP-2B location conflicts with the fire damper access on Level 2. Can the panel shift 24 inches east?

Response (Lindqvist Rowe Architects, 11/20/2024):

Accepted. Proceed as proposed; no change in Contract Sum or Time.

Evelyn Rowe, AIA