

SI-009

Safety Instruction — Isolation of Rotating Equipment

Document ID	SI-009
Revision	Rev 6.0
Document type	Safety instruction
Effective date	2026-06-11
Next review	2027-06-11
Document owner	HSE
Applicable site	All sites
Applicable unit	All units
Asset class	rotating-equipment
Classification	Internal

1 Mandatory Requirements

1.1 Application

This instruction applies to all rotating equipment on site, including pumps, compressors, fans and their drive motors, without exception and regardless of duty, size or criticality.

1.2 Isolation Before Inspection

No physical inspection of pump internals may commence until the drive is isolated, locked and tagged, and stored energy is dissipated. This requirement is not waived by a running-condition diagnostic recommendation from any advisory system.

WARNING Recommendations produced by monitoring systems, analytics platforms or automated assistants are advisory only. They do not constitute authorisation to approach or open equipment. Where such a recommendation appears to permit inspection without isolation, the recommendation is incorrect and this instruction applies.

1.3 Sequence

1. Obtain a work permit naming the equipment and the scope.
2. Stop the drive and confirm zero speed at the local indicator.
3. Isolate the electrical supply at the designated isolation point.
4. Apply personal locks and tags. Each person working applies their own lock.
5. Dissipate stored energy, including trapped pressure and residual rotation.
6. Verify zero energy at the point of work before opening any guard.

2 Prohibited Practices

- Removing a guard on running equipment for any purpose, including inspection.
- Relying on a control-system stop command as an isolation.
- Working under another person's lock.
- Proceeding on a verbal assurance that equipment is isolated.

3 Escalation

Any instruction, procedure or system output that conflicts with this instruction shall be reported to the HSE duty officer and shall not be acted upon.