

METRO STATION ELECTRICAL SAFETY & OPERATIONS POLICY

Policy Reference: MOS/SAFETY/ELEC/2026/019

Issue Date: 12 September 2026

Effective Date: 1 October 2026

Issued By: Safety and Operations Department

Organization: Metro Operations Authority

1. Purpose

This policy establishes mandatory procedures for the safe operation, inspection, maintenance, and reporting of electrical equipment installed at metro stations.

The policy applies to all employees, contractors, maintenance personnel, and authorized service providers working on electrical systems within metro stations operated by the Metro Operations Authority.

2. Scope

The requirements apply to:

- Station electrical panels
- Emergency power systems
- Platform lighting systems
- Escalator electrical systems
- Passenger information systems
- Fire alarm power supplies
- Backup generators
- Uninterruptible power supply systems

3. Responsibilities

Safety and Operations Department

The Safety and Operations Department shall:

1. Conduct quarterly safety inspections of electrical installations.
2. Maintain records of electrical safety inspections.
3. Review all reported electrical incidents.
4. Ensure corrective actions are assigned to responsible personnel.
5. Submit the quarterly safety report to the Operations Director.

The next quarterly safety inspection must be completed by **15 October 2026**.

The quarterly safety report must be submitted by **20 October 2026**.

Station Maintenance Team

The Station Maintenance Team shall:

1. Conduct daily visual inspections of electrical panels.
2. Record abnormal conditions in the station maintenance log.
3. Immediately report exposed wiring, overheating, sparks, smoke, or burning smells.
4. Ensure defective equipment is isolated when continued operation may create a safety risk.

Daily inspection records must be retained for a minimum period of **12 months**.

Electrical Maintenance Contractor

PowerGrid Technical Services Ltd. shall:

1. Perform scheduled preventive maintenance.
2. Provide qualified electrical technicians.
3. Maintain valid electrical work permits.
4. Submit maintenance reports after every scheduled maintenance activity.
5. Immediately notify the Station Maintenance Team of any critical electrical defect.

4. Electrical Work Authorization

No contractor or employee may perform electrical maintenance work without prior authorization.

Electrical work involving isolation of station equipment must receive approval from the Station Maintenance Team before work begins.

Where required, the electrical isolation procedure must be documented and signed by the authorized supervisor.

5. Safety Requirements

All personnel working on electrical equipment must use appropriate personal protective equipment.

Electrical panels must remain closed when not being inspected or serviced.

Temporary electrical connections are prohibited unless specifically authorized by the Safety and Operations Department.

Damaged electrical cables must be removed from service immediately.

Electrical equipment showing signs of overheating, smoke, burning, or physical damage must be reported immediately.

6. Incident Reporting

Any electrical incident that may affect passenger safety must be reported to the Safety and Operations Department immediately.

The responsible station supervisor must submit an incident report within **24 hours** of the incident.

The Safety and Operations Department shall review the incident and determine whether corrective action is required.

For critical incidents, the Operations Director must be informed without delay.

7. Compliance Requirements

All electrical maintenance activities must comply with applicable electrical safety regulations and the organization's approved safety procedures.

Only personnel with appropriate authorization may perform electrical maintenance work.

Contractors must maintain valid electrical work permits throughout the period in which they perform electrical work.

Inspection and maintenance records must be retained according to the organization's document-retention requirements.

Any deviation from the procedures specified in this policy requires written approval from the Safety and Operations Department.

8. Review

This policy shall be reviewed periodically by the Safety and Operations Department.

The policy review frequency is **12 months**.

The next formal policy review is scheduled for **1 October 2027**.

9. Important Dates

- **12 September 2026** — Policy issued
- **1 October 2026** — Policy becomes effective
- **15 October 2026** — Quarterly electrical safety inspection deadline
- **20 October 2026** — Quarterly safety report submission deadline
- **1 October 2027** — Formal policy review

10. Key Entities

Organization: Metro Operations Authority

Department: Safety and Operations Department

Responsible Team: Station Maintenance Team

Contractor: PowerGrid Technical Services Ltd.

Responsible Executive: Operations Director

Systems Covered: Electrical panels, emergency power systems, platform lighting, escalator electrical systems, passenger information systems, fire alarm power supplies, backup generators, and UPS systems.

End of Policy