AwanSolveAi

Repair Work Order

Synthetic dealer work order

Field	Value
Work Order	WO-00008
Claim ID	DEMO-008
Model	DG175
Serial	GEN-175-22891
Operating Hours	4172
Opened	2026-09-09
Closed	2026-09-10

Complaint

Generator cranks but does not start.

Technician Findings

Fuel rail pressure checked during diagnosis.

Repair

Replaced fuel pressure sensor

Technician

Technician H

SYNTHETIC DEMONSTRATION DOCUMENT - NOT AN ACTUAL OEM OR CUSTOMER RECORD