AwanSolveAi

Repair Work Order

Synthetic dealer work order

Field	Value
Work Order	WO-00009
Claim ID	DEMO-009
Model	DG175
Serial	GEN-175-22891
Operating Hours	4127
Opened	2026-09-10
Closed	2026-09-11

Complaint

Generator cranks but does not start.

Technician Findings

Fuel rail pressure checked during diagnosis.

Repair

Replaced fuel pressure sensor

Technician

Technician I

SYNTHETIC DEMONSTRATION DOCUMENT - NOT AN ACTUAL OEM OR CUSTOMER RECORD