AwanSolveAi

Technician Repair Narrative

Synthetic technician narrative

Field	Value
Claim ID	DEMO-021
Technician	Technician A
Equipment	Compressor

Complaint

Low discharge pressure and extended recovery time.

Diagnosis

Performed Discharge pressure.

Cause

Discharge valve leakage

Correction

Replaced discharge valve assembly. Installed part DV-903.

Final Note

Repair completed and machine returned to service.

SYNTHETIC DEMONSTRATION DOCUMENT - NOT AN ACTUAL OEM OR CUSTOMER RECORD