Diagnostic Record

AwanSolveAi validation corpus

Field	Value
Claim ID	A-016
Asset Model	G136
Serial Number	GN-9016
Final Test Date	2026-08-18

Diagnostic Procedure

AC output stability test

Diagnostic Measurement

398 V

Final Test Result

Operational verification completed - PASS

Battery Voltage

NOT RECORDED

Generator Output Voltage

400 V

Frequency

50.0 Hz

Load Bank Test

80% rated load for 25 minutes - PASS

SYNTHETIC DEMONSTRATION DOCUMENT - NOT AN ACTUAL OEM OR CUSTOMER RECORD