Service Work Order

AwanSolveAi validation corpus

Field	Value
Claim No.	A-016
Machine Model	G136
Machine Serial	GN-9016
Machine Hours	2092
Repair Opened	2026-08-17
Repair Completed	2026-08-18

Reported Symptom

Generator starts but voltage is unstable under load.

Repair Performed

Repaired AVR feedback connector and verified output

SYNTHETIC DEMONSTRATION DOCUMENT - NOT AN ACTUAL OEM OR CUSTOMER RECORD