Service Work Order

AwanSolveAi validation corpus

Field	Value
Claim No.	A-017
Machine Model	G137
Machine Serial	GN-9017
Machine Hours	2129
Repair Opened	2026-08-18
Repair Completed	2026-08-19

Reported Symptom

Generator starts but voltage is unstable under load.

Repair Performed

Repaired AVR feedback connector and verified output

SYNTHETIC DEMONSTRATION DOCUMENT - NOT AN ACTUAL OEM OR CUSTOMER RECORD