Service Work Order

AwanSolveAi validation corpus

Field	Value
Claim No.	A-020
Machine Model	G140
Machine Serial	GN-9020
Machine Hours	2240
Repair Opened	2026-08-01
Repair Completed	2026-08-02

Reported Symptom

Generator starts but voltage is unstable under load.

Repair Performed

Repaired AVR feedback connector and verified output

SYNTHETIC DEMONSTRATION DOCUMENT - NOT AN ACTUAL OEM OR CUSTOMER RECORD