Service Work Order

AwanSolveAi validation corpus

Field	Value
Claim No.	A-021
Machine Model	G141
Machine Serial	GN-9021
Machine Hours	2277
Repair Opened	2026-08-02
Repair Completed	2026-08-03

Reported Symptom

Generator starts but voltage is unstable under load.

Repair Performed

Repaired AVR feedback connector and verified output

SYNTHETIC DEMONSTRATION DOCUMENT - NOT AN ACTUAL OEM OR CUSTOMER RECORD