Service Work Order

AwanSolveAi validation corpus

Field	Value
Claim No.	A-022
Machine Model	G142
Machine Serial	GN-9022
Machine Hours	2314
Repair Opened	2026-08-03
Repair Completed	2026-08-04

Reported Symptom

Generator starts but voltage is unstable under load.

Repair Performed

Repaired AVR feedback connector and verified output

SYNTHETIC DEMONSTRATION DOCUMENT - NOT AN ACTUAL OEM OR CUSTOMER RECORD