Warranty Repair Claim Summary

AwanSolveAi validation corpus

Field	Value
Claim Number	A-025
Equipment Type	Generator
Asset Model	G145
Asset Serial Number	GN-9025
Meter Hours	2425
Customer Concern	Generator starts but voltage is unstable under load.
Diagnostic Code	AVR-21
Root Cause	Automatic voltage regulator feedback connector had high resistance
Corrective Action	Repaired AVR feedback connector and verified output
Replacement Part	CONN-AVR
Labor Claimed	2.8 hours

SYNTHETIC DEMONSTRATION DOCUMENT - NOT AN ACTUAL OEM OR CUSTOMER RECORD