Diagnostic Record

AwanSolveAi validation corpus

Field	Value
Claim ID	A-025
Asset Model	G145
Serial Number	GN-9025
Final Test Date	2026-07-01

Diagnostic Procedure

AC output stability test

Diagnostic Measurement

398 V

Final Test Result

Operational verification completed - PASS

Battery Voltage

25.4 V

Generator Output Voltage

400 V

Frequency

50.0 Hz

Load Bank Test

80% rated load for 25 minutes - PASS

SYNTHETIC DEMONSTRATION DOCUMENT - NOT AN ACTUAL OEM OR CUSTOMER RECORD