Service Work Order

AwanSolveAi validation corpus

Field	Value
Claim No.	A-025
Machine Model	G145
Machine Serial	GN-9025
Machine Hours	2425
Repair Opened	2026-08-06
Repair Completed	2026-08-07

Reported Symptom

Generator starts but voltage is unstable under load.

Repair Performed

Repaired AVR feedback connector and verified output

SYNTHETIC DEMONSTRATION DOCUMENT - NOT AN ACTUAL OEM OR CUSTOMER RECORD