Test and Verification Record

AwanSolveAi External Validation Pack V1

Field	Value
Claim No.	EXT-004
Asset Model	ANA-G180
Serial Number	ANA18-8204
Final Test Date	2026-09-18

Diagnostic Procedure

Control signal and output stability test

Diagnostic Measurement

398 V

Final Test Result

Final operational test completed - PASS

Battery Voltage

25.6 V

Generator Output Voltage

400 V

Frequency

50.0 Hz

Load Bank Test

75% rated load for 30 minutes - PASS

SYNTHETIC EXTERNAL-VALIDATION DOCUMENT - NOT AN ACTUAL OEM OR CUSTOMER RECORD