Compressor Warranty Claim

AwanSolveAi External Set C

Field	Value
Warranty Claim Number	EXTC-006
Equipment Type	Rotary Screw Compressor
Compressor Model	FA-RS75
Compressor Serial Number	FA75-1206
Rotary Total Hours	1902
Description of Warranty Failure	Intermittent loss of performance occurs after extended operation.
Failure Code	C-88
Failure Diagnosis	Control feedback connection developed intermittent resistance.
Warranty Service Completed	Connection repaired, terminals secured, and operation retested.
Parts Replaced	PT-8842
Technician Labor Hours	3.0 hours
Date of Start Up	2026-04-02
Date of Warranty Failure	2026-09-23
Date of Warranty Completion	2026-09-26
Load Hours	1210
Control Voltage	24 V
Operating Pressure	9 bar

SYNTHETIC EXTERNAL HOLDOUT DOCUMENT - NOT AN ACTUAL OEM OR CUSTOMER RECORD