Service Work Order

AwanSolveAi validation corpus

Field	Value
Claim No.	A-003
Machine Model	G123
Machine Serial	GN-9003
Machine Hours	1611
Repair Opened	2026-08-04
Repair Completed	2026-08-05

Reported Symptom

Generator starts but voltage is unstable under load.

Repair Performed

Repaired AVR feedback connector and verified output

SYNTHETIC DEMONSTRATION DOCUMENT - NOT AN ACTUAL OEM OR CUSTOMER RECORD