Service Work Order

AwanSolveAi validation corpus

Field	Value
Claim No.	A-006
Machine Model	G126
Machine Serial	GN-9006
Machine Hours	1722
Repair Opened	2026-08-07
Repair Completed	2026-08-08

Reported Symptom

Generator starts but voltage is unstable under load.

Repair Performed

Repaired AVR feedback connector and verified output

SYNTHETIC DEMONSTRATION DOCUMENT - NOT AN ACTUAL OEM OR CUSTOMER RECORD