Service Work Order

AwanSolveAi validation corpus

Field	Value
Claim No.	A-009
Machine Model	G129
Machine Serial	GN-9009
Machine Hours	1833
Repair Opened	2026-08-10
Repair Completed	2026-08-11

Reported Symptom

Generator starts but voltage is unstable under load.

Repair Performed

Repaired AVR feedback connector and verified output

SYNTHETIC DEMONSTRATION DOCUMENT - NOT AN ACTUAL OEM OR CUSTOMER RECORD