Service Work Order

AwanSolveAi validation corpus

Field	Value
Claim No.	A-012
Machine Model	G132
Machine Serial	GN-9012
Machine Hours	1944
Repair Opened	2026-08-13
Repair Completed	2026-08-14

Reported Symptom

Generator starts but voltage is unstable under load.

Repair Performed

Repaired AVR feedback connector and verified output

SYNTHETIC DEMONSTRATION DOCUMENT - NOT AN ACTUAL OEM OR CUSTOMER RECORD