# Service Work Order

AwanSolveAi validation corpus

| Field | Value |
|---|---|
| Claim No. | A-015 |
| Machine Model | G135 |
| Machine Serial | GN-9015 |
| Machine Hours | 2055 |
| Repair Opened | 2026-08-16 |
| Repair Completed | 2026-08-17 |

## Reported Symptom

Generator starts but voltage is unstable under load.

## Repair Performed

Repaired AVR feedback connector and verified output

SYNTHETIC DEMONSTRATION DOCUMENT - NOT AN ACTUAL OEM OR CUSTOMER RECORD