Service Work Order

AwanSolveAi validation corpus

Field	Value
Claim No.	A-018
Machine Model	G138
Machine Serial	GN-9018
Machine Hours	2166
Repair Opened	2026-08-19
Repair Completed	2026-08-20

Reported Symptom

Generator starts but voltage is unstable under load.

Repair Performed

Repaired AVR feedback connector and verified output

SYNTHETIC DEMONSTRATION DOCUMENT - NOT AN ACTUAL OEM OR CUSTOMER RECORD