# Diagnostic Record

AwanSolveAi validation corpus

| Field | Value |
|---|---|
| Claim ID | A-024 |
| Asset Model | G144 |
| Serial Number | GN-9024 |
| Final Test Date | 2026-08-06 |

## Diagnostic Procedure

AC output stability test

# Measured Results and Final Verification

### Diagnostic Measurement

398 V

### Final Test Result

Operational verification completed - PASS

### Battery Voltage

25.4 V

### Generator Output Voltage

400 V

### Frequency

50.0 Hz

### Load Bank Test

80% rated load for 25 minutes - PASS

SYNTHETIC DEMONSTRATION DOCUMENT - NOT AN ACTUAL OEM OR CUSTOMER RECORD