Service Work Order

AwanSolveAi validation corpus

Field	Value
Claim No.	A-019
Machine Model	G139
Machine Serial	GN-9019
Machine Hours	2203
Repair Opened	2026-08-20
Repair Completed	2026-08-21

Reported Symptom

Generator starts but voltage is unstable under load.

Repair Performed

Repaired AVR feedback connector and verified output

SYNTHETIC DEMONSTRATION DOCUMENT - NOT AN ACTUAL OEM OR CUSTOMER RECORD