

MAINTENANCE RECORD - October 15, 2023

Equipment Tag: C-101 (Main Air Compressor)

Technician: Jane Smith

Supervisor: John Doe

Summary of Work:

Conducted annual inspection of C-101 following the Q3 pressure trip incident.

Replaced the primary seal and tested the vibration sensors.

Observed minor wear on the impeller, but it is within operational limits.

Regulatory Compliance:

This inspection satisfies the requirements of OSHA standard 1910.119 (Process Safety Management).