



GRIZZLY Public School



CBSE Curriculum, English Medium Day School

Affiliation Code : KODEDN (Elementary) - 008, U-Dise Code : 20050127210

Ref. No. Gps/AC-199/41

Dated 15-09-26

To
The Executive Engineer
Drinking Water and Sanitation Department (DWSD)
Jhumri Telaiya, Koderma, Jharkhand

Subject: Request for Issuance of Water and Sanitation Certificate.

Respected Sir/Madam,


With reference to the CBSE guideline our school requires a certificate for safe drinking water and sanitation Certificate.

We would like to inform you that Grizzly Public School is established in the year 2015, is situated at Satpulia, Gumo, Jhumri Telaiya, Koderma.

As per the guideline, the certificate regarding safe drinking water and sanitation safety needs to be submitted. Therefore, we request your kind consideration for issuance of the required certificate.

We shall be grateful for your cooperation and support in this regard.

Yours faithfully,


17/9/26

Mrs. Niraja
Principal

Grizzly Public School
Jhumri Telaiya, Koderma
(Jharkhand) - 825409



Website

School Address: Near Grizzly College of Education, Satpulia, Gumo, P.O. - Jhumritelaiya - 825409, Dist. - Koderma (Jharkhand)
Contact No. # 9102990116, Office : 7070098765, E-mail : info@grizzlyjmt.com
Correspondence Address: 3rd Floor, Ujala Complex, Near Smart Bazar, Jhumri Telaiya, Koderma - 825409. Mob. # 7070098762



Facebook

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 56

Dated: 23/03/2026

It is certified that an inspection team headed by Sri. Suraj Kumar Das.....

(Name of Officers with designation) from DWS Subdivision Italiya PHED

Inspected the BRILLY Public School Thumri Teliya.....

(Name & Address of the school) on 16/03/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. JMT/DWTL/S-08 dated 19/03/26

of Dist Level Water Testing Lab (PHED Lab) certified that the

BRILLY Public School Italiya..... (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till Six Month only

Signature with Seal: 23/03/26

Name: Sri. Suraj Kumar Das

Designation: S.D.O. S.D.O.

Name & Address of the Office / Department: Dist. & Sub.

DIV. J. Teliya

To

Principal
BRILLY Public School
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



TC-15652

District Level Water Testing Laboratory
Office of the Executive Engineer, Drinking Water and Sanitation Division,
Jhumritelaiya-825409, Jharkhand, India.
Contact No.-9123276372. Email: dlwtl.jhumritelaiya@gmail.com

TEST REPORT

Issued to :- Principal- Mrs Nirja Sampling Location- GRIZZLY Public School Jhumri Telaiya Dist-Koderma(Jharkhand) 825409	Sample Code:-JMT/DLWTL/S-08 URL NO. :- TC156520250000029F Date of Issue :- 19-03-2026
--	---

SAMPLE PARTICULARS

Sample Name/Description :- GW Sample Quantity :- 01 L Sample pkg. Condition :- Good Condition at 4°C Number of samples : 1 No Sample Receive date :- 16-03-2026	Customer Date of sampling :- 16-03-2026 Customer Reference No. :- 20260316-08 Test started on 17-03-2026 Test completed on :- 19-03-2026
---	---

TEST RESULT

Sl. No.	Tested Parameter	Unit	Results	Method	Specification as per IS 10500 : 2012 (Second Revision)	
					Acceptable Limit	Permissible Limit (Absence of Alternate source)
1	pH	-	7.29	APHA 24 th Ed.2023-4500-H- B, (Electrometric method)	6.5 – 8.5	No relaxation
2	Turbidity	NTU	4.5	APHA 24 th Ed.2023-2130 B, (Nephelometric method)	1	5
3	Total Alkalinity as CaCO ₃	mg/l	262	APHA 24 th Ed.2023-2320 B, (Titration method)	200	600
4	Calcium as (Ca)	mg/l	89.77	APHA 24 th Ed.2023-3500 Ca B, (EDTA Titration method)	75	200
5	Magnesium as Mg	mg/l	14.58	APHA 24 th Ed.2023-3500-Mg B, (Calculation method)	30	100
6	Total Hardness as CaCO ₃	mg/l	282	APHA 24 th Ed.2023-2340 C, (EDTA Titration method)	200	600
7	Fluoride as (F)	mg/l	0.8	APHA 24 th Ed.2023-4500 F -C, (Ion selective electrode method)	1.0	1.5
8	Taste	-	Agreeable	APHA 24 th Ed.2023-2160 C (Taste Threshold)	Satisfactory	No relaxation
9	Odour	-	Agreeable	IS 3025 (Part-5)	Satisfactory	No relaxation
10	Colour	Hazen	8	APHA 24 th Ed.2023-2120 B (Visual Comparison Method)	5	15
11	Total Dissolved Solids	mg/l	380	APHA 24 th Ed.2023-2540 C (Total Dissolved Solids Dried at 180 Degree C)	500	2000
12	Chloride (as cl)	mg/l	79	APHA 24 th Ed.2023-4500-CL Method B (Argentometric method)	250	1000

Remarks:-Submitted Sample of Water according to above parameters is fit for Consumption:- Yes ☒ / No ()
Specific contractual notes: - (validity six month for date of issue)

- ◆ The results listed refer only to the tested sample and applicable parameter as received from the customer.
- ◆ This report shall not be reproduced except in full without approval of the laboratory.
- ◆ This report, in full or in part, shall not be used for advertising or as evidence in any court of law.
- ◆ Tested Sample shall be retained up to seven days from the date of issue of the test report.
- ◆ All disputes are subjected to the Koderma Jurisdiction.
- ◆ NOTE:- Beyond Detection Limit.

B 19/03/2026
Reviewed By
Q.M

Ram Kumar Prasad
19/03/2026
Authorized By
(Quality Manager)
Ram Kumar Prasad
Quality Manager
District Level Water Testing Laboratory
Jhumritelaiya, Jharkhand

End of Report