SCHEDULE										
NIT.No.			42/SE (Elec.)/TTD/2026-27		Schedule down load start date		23.10.2026 at 5.00 pm		
					Download end date		07.11.2026 at 1.00 pm		
Name fo work :			Providing Electrical lighting to Development of landscape (Soft scape & Hardscape) works in Divya Aushadha vanam Park (3.9 Acres) at Tirumala.		Last date for submission		07.11.2026 at 3.00 pm		
					EMD at the time of Tender		₹ 55,000.00		
					EMD at the time of Agreement		2.5% of TCV - EMD at the time of tender		
					Time for completion		SIX (6) months		
					Form of Agreement		LS		
S.No.	Qty		Description of Item	work type (UPTO 200 characters)	Item short description (upto 100 characters)	APSS/ Morth Cl. Numb	Rate in ₹	Unit	Amount in ₹
1	600	m	Supply and fixing of Surface mounted flexible LED strip (Excluding driver) of system power 5W/m with the following specification without driver	Supply and fixing of Surface mounted flexible LED strip (Excluding driver) of system power 5W/m with the following specification without driver	Supply and fixing of Surface mounted flexible LED strip (Excluding driver) of system power 5W/m with	NA	3,150.00	RMT	18,90,000.00
	0	NA	a) Wattage : <5W/m (Tolerance allowed as per IS16103)	a) Wattage : <5W/m (Tolerance allowed as per IS16103)	a) Wattage : <5W/m (Tolerance allowed as per IS16103)	NA	0.00	NA	0.00
	0	NA	b) SDCM : <5	b) SDCM : <5	b) SDCM : <5	NA	0.00	NA	0.00
	0	NA	c) Lumen output : >400 Lumens/m	c) Lumen output : >400 Lumens/m	c) Lumen output : >400 Lumens/m	NA	0.00	NA	0.00
	0	NA	d) CRI : >80	d) CRI : >80	d) CRI : >80	NA	0.00	NA	0.00
	0	NA	e) CCT : 3000K	e) CCT : 3000K	e) CCT : 3000K	NA	0.00	NA	0.00
	0	NA	f) The LED strip shall have a clear silicon encapsulation with ingress protection of IP65.	f) The LED strip shall have a clear silicon encapsulation with ingress protection of IP65.	f) The LED strip shall have a clear silicon encapsulation with ingress protection of IP65.	NA	0.00	NA	0.00
	0	NA	g) Beam Angle: >110°	g) Beam Angle: >110°	g) Beam Angle: >110°	NA	0.00	NA	0.00
	0	NA	h) The LED strip shall be supplied along with the 20-25mm Aluminium profile with 2mm thickness.	h) The LED strip shall be supplied along with the 20-25mm Aluminium profile with 2mm thickness.	h) The LED strip shall be supplied along with the 20-25mm Aluminium profile with 2mm thickness.	NA	0.00	NA	0.00
	0	NA	i) Warranty : 5 Years	i) Warranty : 5 Years	i) Warranty : 5 Years	NA	0.00	NA	0.00
	0	NA	Note: The Non-integral driver shall be provided at remote location as directed by the department. The luminaire shall comply with the IEC standards or their Indian equivalents. The IEC/BIS certificates for the luminaire has to be provided	Note: The Non-integral driver shall be provided at remote location as directed by the department. The luminaire shall comply with the IEC standards or their Indian equivalents. The IEC/BIS certificate	Note: The Non-integral driver shall be provided at remote location as directed by the department. Th	NA	0.00	NA	0.00
	0	NA	**Makes:** Philips BGC201 / Equivalent in Osram / K-lite.	Makes: Philips BGC201 / Equivalent in Osram / K-lite.	Makes: Philips BGC201 / Equivalent in Osram / K-lite.	NA	0.00	NA	0.00

S.No.	Qty		Description of Item	work type (UPTO 200 characters)	Item short description (upto 100 characters)	APSS/ Morth Cl. Numb	Rate in ₹	Unit	Amount in ₹
2	**28**	**Nos.**	**Supply and fixing of 34W post top/street light luminaire with the following specification**	**Supply and fixing of 34W post top/street light luminaire with the following specification**	**Supply and fixing of 34W post top/street light luminaire with the following specification**	**NA**	**12,760.00**	**Each**	**3,57,280.00**
	0	NA	a) Wattage: < 34W LED (Tolerance allowed as per IS16103)	a) Wattage: < 34W LED (Tolerance allowed as per IS16103)	a) Wattage: < 34W LED (Tolerance allowed as per IS16103)	NA	0.00	NA	0.00
	0	NA	b) SDCM: < 5	b) SDCM: < 5	b) SDCM: < 5	NA	0.00	NA	0.00
	0	NA	c) Lumen output: >4000 lm	c) Lumen output: >4000 lm	c) Lumen output: >4000 lm	NA	0.00	NA	0.00
	0	NA	d) CRI (Ra) : >70	d) CRI (Ra) : >70	d) CRI (Ra) : >70	NA	0.00	NA	0.00
	0	NA	e) CCT : 3000K	e) CCT : 3000K	e) CCT : 3000K	NA	0.00	NA	0.00
	0	NA	f) Driver Integral: Constant Current	f) Driver Integral: Constant Current	f) Driver Integral: Constant Current	NA	0.00	NA	0.00
	0	NA	g) Surge protection : >6kV SPD	g) Surge protection : >6kV SPD	g) Surge protection : >6kV SPD	NA	0.00	NA	0.00
	0	NA	h) The luminaire shall have Ingress protection of IP65	h) The luminaire shall have Ingress protection of IP65	h) The luminaire shall have Ingress protection of IP65	NA	0.00	NA	0.00
	0	NA	i) Housing : Pressure die cast Al	i) Housing : Pressure die cast Al	i) Housing : Pressure die cast Al	NA	0.00	NA	0.00
	0	NA	j) Beam Angle : 120°	j) Beam Angle : 120°	j) Beam Angle : 120°	NA	0.00	NA	0.00
	0	NA	Note: The integral driver and the luminaire shall comply with the IEC standards or their Indian equivalents. The BIS certificates for both the luminaire and the driver has to be provided	Note: The integral driver and the luminaire shall comply with the IEC standards or their Indian equivalents. The BIS certificates for both the luminaire and the driver has to be provided	Note: The integral driver and the luminaire shall comply with the IEC standards or their Indian equi	NA	0.00	NA	0.00
	0	NA	**Makes:** Philips - BSS461 LED40 / Equivalent of Osram / K-Lite	Makes: Philips - BSS461 LED40 / Equivalent of Osram / K-Lite	Makes: Philips - BSS461 LED40 / Equivalent of Osram / K-Lite	NA	0.00	NA	0.00
3	**28**	**Nos.**	**Supply of 4.27 mters height decorative street/ garden lighting pole (NAMAM Bracket) with single arm with Mild steel pipe with zinc rich primer & pure polyster powder coating and finishing with polyurethane based paint with all accessories such as suitable base plates, bolts & nuts etc., complete.**	**Supply of 4.27 mters height decorative street/ garden lighting pole (NAMAM Bracket) with single arm with Mild steel pipe with zinc rich primer & pure polyster powder coating and finishing with polyu**	**Supply of 4.27 mters height decorative street/ garden lighting pole (NAMAM Bracket) with single ar**	**NA**	**26,000.00**	**Each**	**7,28,000.00**
	0	NA	Warranty : 5 years	Warranty : 5 years	Warranty : 5 years	NA	0.00	NA	0.00
			Make : Klite-KP 5137/ Equivalent of Osram	Make :Klite-KP 5137/ Equivalent of Osram	Make :Klite-KP 5137/ Equivalent of Osram	NA	0.00	NA	0.00
4	**20**	**Nos.**	**Supply and fixing of 30W post top fixture with the following specification**	**Supply and fixing of 30W post top fixture with the following specification**	**Supply and fixing of 30W post top fixture with the following specification**	**NA**	**26,200.00**	**Each**	**5,24,000.00**
	0	NA	a) Wattage: < 30W (Tolerance allowed as per IS16103)	a) Wattage: < 30W (Tolerance allowed as per IS16103)	a) Wattage: < 30W (Tolerance allowed as per IS16103)	NA	0.00	NA	0.00
	0	NA	b) SDCM: < 5 for better consistency	b) SDCM: < 5 for better consistency	b) SDCM: < 5 for better consistency	NA	0.00	NA	0.00

S.No.	Qty		Description of Item	work type (UPTO 200 characters)	Item short description (upto 100 characters)	APSS/ Morth Cl. Numb	Rate in ₹	Unit	Amount in ₹
	0	NA	c) Lumen output: >3000 Lm	c) Lumen output: >3000 Lm	c) Lumen output: >3000 Lm	NA	0.00	NA	0.00
	0	NA	d) CRI (Ra) : >70	d) CRI (Ra) : >70	d) CRI (Ra) : >70	NA	0.00	NA	0.00
	0	NA	e) CCT : 3000K	e) CCT : 3000K	e) CCT : 3000K	NA	0.00	NA	0.00
	0	NA	f) Driver Integral: Constant Current	f) Driver Integral: Constant Current	f) Driver Integral: Constant Current	NA	0.00	NA	0.00
	0	NA	g) THD : <10%	g) THD : <10%	g) THD : <10%	NA	0.00	NA	0.00
	0	NA	h) PF : >0.9	h) PF : >0.9	h) PF : >0.9	NA	0.00	NA	0.00
	0	NA	i) Surge protection : >6kV	i) Surge protection : >6kV	i) Surge protection : >6kV	NA	0.00	NA	0.00
	0	NA	j) The luminaire shall have Ingress protection of IP65	j) The luminaire shall have Ingress protection of IP65	j) The luminaire shall have Ingress protection of IP65	NA	0.00	NA	0.00
	0	NA	k) Housing : Pressure die cast Al	k) Housing : Pressure die cast Al	k) Housing : Pressure die cast Al	NA	0.00	NA	0.00
	0	NA	l) Beam Angle : 90°*90°	l) Beam Angle : 90°*90°	l) Beam Angle : 90°*90°	NA	0.00	NA	0.00
	0	NA	m) Warranty:5 years	m) Warranty:5 years	m) Warranty:5 years	NA	0.00	NA	0.00
	0	NA	Note:	Note:	Note:	NA	0.00	NA	0.00
	0	NA	1. Golden finishing crown has to be provided on the top of the luminairie as directed by the department	1. Golden finishing crown has to be provided on the top of the luminairie as directed by the department	1. Golden finishing crown has to be provided on the top of the luminairie as directed by the departm	NA	0.00	NA	0.00
	0	NA	2. The integral driver and the luminaire shall comply with the IEC standards or their Indian equivalents. The BIS certificates for both the luminaire and the driver has to be provided	2. The integral driver and the luminaire shall comply with the IEC standards or their Indian equivalents. The BIS certificates for both the luminaire and the driver has to be provided	2. The integral driver and the luminaire shall comply with the IEC standards or their Indian equival	NA	0.00	NA	0.00
	0	NA	**Make:** Similar to Philips : BDP461 / Equivalent in Osram/ K-lite	Make: Similar to Philips : BDP461 / Equivalent in Osram/ K-lite	Make: Similar to Philips : BDP461 / Equivalent in Osram/ K-lite	NA	0.00	NA	0.00
5	**20**	**Nos.**	**Supply and fixing of 3 meters height Pole with Mild steel pipe with Zinc rich primer & pure polyester powder coating and finishing with polyurethane based paint with all accessories such as suitable base plates, bolts & nuts etc., complete**	**Supply and fixing of 3 meters height Pole with Mild steel pipe with Zinc rich primer & pure polyester powder coating and finishing with polyurethane based paint with all accessories such as suitable b**	**Supply and fixing of 3 meters height Pole with Mild steel pipe with Zinc rich primer & pure polyeste**	**NA**	**13,800.00**	**Each**	**2,76,000.00**
	0	NA	Warranty : 5 years	Warranty : 5 years	Warranty : 5 years	NA	0.00	NA	0.00
	0	NA	Note: Golden finishing for the floral design areas has to be provided as directed by the department.	Note: Golden finishing for the floral design areas has to be provided as directed by the department.	Note: Golden finishing for the floral design areas has to be provided as directed by the department.	NA	0.00	NA	0.00
	0	NA	**Make** :Klite-KP 4189	Make :Klite-KP 4189	Make :Klite-KP 4189	NA	0.00	NA	0.00

S.No.	Qty		Description of Item	work type (UPTO 200 characters)	Item short description (upto 100 characters)	APSS/ Morth Cl. Numb	Rate in ₹	Unit	Amount in ₹
6	**65**	**Nos.**	**Supply and fixing of 7W tree uplighter (Garden spike) with pressured Die-cast aluminium alloy body & Clear Toughened Glass diffuser with the following specification**	**Supply and fixing of 7W tree uplighter (Garden spike) with pressured Die-cast aluminium alloy body & Clear Toughened Glass diffuser with the following specification**	**Supply and fixing of 7W tree uplighter (Garden spike) with pressured Die-cast aluminium alloy body &**	**NA**	**4,485.00**	**Each**	**2,91,525.00**
	0	NA	a) Wattage: <7W(Tolerance allowed as per IS16103)	a) Wattage: <7W(Tolerance allowed as per	a) Wattage: <7W(Tolerance	NA	0.00	NA	0.00
	0	NA	b) SDCM: <5	b) SDCM: <5	b) SDCM: <5	NA	0.00	NA	0.00
	0	NA	c) Lumen output: >360 lm	c) Lumen output: >360 lm	c) Lumen output: >360 lm	NA	0.00	NA	0.00
	0	NA	d) CRI (Ra) : >80	d) CRI (Ra) : >80	d) CRI (Ra) : >80	NA	0.00	NA	0.00
	0	NA	e) CCT : 3000K/ 4000K	e) CCT : 3000K/ 4000K	e) CCT : 3000K/ 4000K	NA	0.00	NA	0.00
	0	NA	f) Driver Integral: Constant Current	f) Driver Integral: Constant Current	f) Driver Integral: Constant Current	NA	0.00	NA	0.00
	0	NA	g) Surge protection : >2kV	g) Surge protection : >2kV	g) Surge protection : >2kV	NA	0.00	NA	0.00
	0	NA	h) The luminaire shall have Impact protection of IK06 and Ingress protection of IP65	h) The luminaire shall have Impact protection of IK06 and Ingress protection of IP65	h) The luminaire shall have Impact protection of IK06 and Ingress protection of IP65	NA	0.00	NA	0.00
	0	NA	i) Beam Angle: 15° / 25° / 40°	i) Beam Angle: 15° / 25° / 40°	i) Beam Angle: 15° / 25° / 40°	NA	0.00	NA	0.00
	0	NA	j) Warranty : 5 years	j) Warranty : 5 years	j) Warranty : 5 years	NA	0.00	NA	0.00
	0	NA	Note: The integral driver and the luminaire shall comply with the IEC standards or their Indian equivalents. The BIS certificates for both the luminaire and the driver has to be provided	Note: The integral driver and the luminaire shall comply with the IEC standards or their Indian equivalents. The BIS certificates for both the luminaire and the driver has to be provided	Note: The integral driver and the luminaire shall comply with the IEC standards or their Indian equi	NA	0.00	NA	0.00
	0	NA	**Make :** Klite KP-7052 / Philips Garden spike / Equivalent in Osram	Make : Klite KP-7052 / Philips Garden spike / Equivalent in Osram	Make : Klite KP-7052 / Philips Garden spike / Equivalent in Osram	NA	0.00	NA	0.00
7	**35**	**Nos.**	**Supply and fixing of 12W Bollard light with pressure Die-cast aluminium body & clear acrylic diffuser with the following specification**	**Supply and fixing of 12W Bollard light with pressure Die-cast aluminium body & clear acrylic diffuser with the following specification**	**Supply and fixing of 12W Bollard light with pressure Die-cast aluminium body & clear acrylic diffuse**	**NA**	**6,100.00**	**Each**	**2,13,500.00**
	0	NA	a) Wattage: <12W	a) Wattage: <12W	a) Wattage: <12W	NA	0.00	NA	0.00
	0	NA	b) SDCM: < 5	b) SDCM: < 5	b) SDCM: < 5	NA	0.00	NA	0.00
	0	NA	c) CRI (Ra) : >80	c) CRI (Ra) : >80	c) CRI (Ra) : >80	NA	0.00	NA	0.00
	0	NA	d) CCT : 2700K/ /3000K/ 4000K/ 5700K	d) CCT : 2700K/ /3000K/ 4000K/ 5700K	d) CCT : 2700K/ /3000K/ 4000K/ 5700K	NA	0.00	NA	0.00
	0	NA	e) Driver Integral: Constant Current	e) Driver Integral: Constant Current	e) Driver Integral: Constant Current	NA	0.00	NA	0.00
	0	NA	f) Surge protection : >3kV	f) Surge protection : >3kV	f) Surge protection : >3kV	NA	0.00	NA	0.00

S.No.	Qty		Description of Item	work type (UPTO 200 characters)	Item short description (upto 100 characters)	APSS/ Morth Cl. Numb	Rate in ₹	Unit	Amount in ₹
	0	NA	g) The luminaire shall have Impact protection of IK10 and Ingress protection of IP65	g) The luminaire shall have Impact protection of IK10 and Ingress protection of IP65	g) The luminaire shall have Impact protection of IK10 and Ingress protection of IP65	NA	0.00	NA	0.00
	0	NA	h) Warranty : 5 years	h) Warranty : 5 years	h) Warranty : 5 years	NA	0.00	NA	0.00
	0	NA	i) Recommended installation height: 300mm	i) Recommended installation height: 300mm	i) Recommended installation height: 300mm	NA	0.00	NA	0.00
	0	NA	Note: The integral driver and the luminaire shall comply with the IEC standards or their Indian equivalents. The BIS certificates for both the luminaire and the driver has to be provided	Note: The integral driver and the luminaire shall comply with the IEC standards or their Indian equivalents. The BIS certificates for both the luminaire and the driver has to be provided	Note: The integral driver and the luminaire shall comply with the IEC standards or their Indian equi	NA	0.00	NA	0.00
	0	NA	**Make:** Klite KP- 7200/ Phillips / Osram	Make: Klite KP- 7200/ Phillips / Osram	Make: Klite KP- 7200/ Phillips / Osram	NA	0.00	NA	0.00
8	**2**	**Nos.**	**Supply of 4 Pole 4 Module 15 KA 1.2 KV Voltage Surge Protector, confirms to IEC/EN 61643-11. Makes: Legrand / Siemens / G.E / L&T / Hager/ Havells**	**Supply of 4 Pole 4 Module 15 KA 1.2 KV Voltage Surge Protector, confirms to IEC/EN 61643-11. Makes: Legrand / Siemens / G.E / L&T / Hager/ Havells**	**Supply of 4 Pole 4 Module 15 KA 1.2 KV Voltage Surge Protector, confirms to IEC/EN 61643-11. Makes:**	**NA**	**14,127.55**	**Each**	**28,255.10**
9	**1**	**No.**	**Supply, Installaltion, Testing and commissioning of free standing floor mounted dust and vermin proof compartmentalized cubical panel made out of CRCA sheet out-door type control pillar box of size 1250mm (W) x 1200mm (H) x 400mm (D) required hardware, duly painted by two coats of zinc/red oxide primer followed by Powder coated / epoxy /PU painted with phosphatisation in grey or required shade after rinsing. The panel having PU/Neoprene rubber gasket of not les than 3 mm thickness, separate detachable, glad plate MS base channel, hinged door with locking arrangement for equipment/switchgear. Thickness of sheet shall not be less than 1.6 mm UP to 600 mm. Load bearing structure shall be of 2.00 mm thick sheet supported by base MS channel if required. Side walls and cable alley compartments having bolted type doors with detachable extension type sturcture (Only outer area on all sides shall be measured and panel to be fabricated from CPRI approved fabricator)**	**Supply, Installaltion, Testing and commissioning of free standing floor mounted dust and vermin proof compartmentalized cubical panel made out of CRCA sheet out-door type control pillar box of size 12**	**Supply, Installaltion, Testing and commissioning of free standing floor mounted dust and vermin proo**	**NA**	**1,81,220.50**	**Each**	**1,81,220.50**
	0	NA	a) Incoming: Supply and fixing of 400A 4-Pole MCCB Adjustable, Confirms to IEC 60947-2 and IS 13947-Part 1&2 having Breaking Capacity 36/35 KA with thermal magnetic release Panel Mounted. Makes: L&T- D shine / Schneider-NS NSX/Legrand -DP X3/ Siemens-3VL / Hagerh3/C&S -Winbreak2 with all necessary spreader links & accessories on suitable support -1 No.	a) Incoming: Supply and fixing of 400A 4-Pole MCCB Adjustable, Confirms to IEC 60947-2 and IS 13947-Part 1&2 having Breaking Capacity 36/35 KA with thermal magnetic release Panel Mounted. Makes: L&T	a) Incoming: Supply and fixing of 400A 4-Pole MCCB Adjustable, Confirms to IEC 60947-2 and IS 13947-	NA	0.00	NA	0.00

S.No.	Qty		Description of Item	work type (UPTO 200 characters)	Item short description (upto 100 characters)	APSS/ Morth Cl. Numb	Rate in ₹	Unit	Amount in ₹
	0	NA	b) Out Goings: Supply and fixing of 125A, 3-Pole MCCB Adjustable, Confirms to IEC 60947-2 and IS 13947-Part 1&2 having Breaking Capacity 25KA with thermal magnetic release Panel Mounted. Makes: L&T- D shine / Schneider-NS NSX/Legrand -DP X3/ Siemens-3VL / Hagerh3/C&S -Winbreak2 with all necessary spreader links & accessories on suitable support- 4 Nos.	b) Out Goings: Supply and fixing of 125A, 3-Pole MCCB Adjustable, Confirms to IEC 60947-2 and IS 13947-Part 1&2 having Breaking Capacity 25KA with thermal magnetic release Panel Mounted. Makes: L&T-	b) Out Goings: Supply and fixing of 125A, 3-Pole MCCB Adjustable, Confirms to IEC 60947-2 and IS 139	NA	0.00	NA	0.00
	0	NA	c) Supply and fixing of Electrolytic grade copper bus bar of size 1" x 1/2" by means of SMC / DMC type insulator, high tensile nuts and bolts spring washers in existing panel including bending, cutting in required shape and size and colour coding with heat shrinkable PVC sleeves - 4 Nos.	c) Supply and fixing of Electrolytic grade copper bus bar of size 1" x 1/2" by means of SMC / DMC type insulator, high tensile nuts and bolts spring washers in existing panel including bending, cutti	c) Supply and fixing of Electrolytic grade copper bus bar of size 1" x 1/2" by means of SMC / DMC t	NA	0.00	NA	0.00
	0	NA	d) The MCCB's should be connect to the bus bars with 2 run of 16 Sq.mm FRLS copper wire of makes:Finolex / RR kabel / APAR E-beam with necessary copper lugs and crimping etc., complete.	d) The MCCB's should be connect to the bus bars with 2 run of 16 Sq.mm FRLS copper wire of makes:Finolex / RR kabel / APAR E-beam with necessary copper lugs and crimping etc., complete.	d) The MCCB's should be connect to the bus bars with 2 run of 16 Sq.mm FRLS copper wire of makes:Fin	NA	0.00	NA	0.00
	0	NA	e) Supply and Fixing of 240/220 V, LED (22.5 mm dia) Pilot lamp with integral circuit, terminal block, including connection etc. as required- 6 No's	e) Supply and Fixing of 240/220 V, LED (22.5 mm dia) Pilot lamp with integral circuit, terminal block, including connection etc. as required- 6 No's	e) Supply and Fixing of 240/220 V, LED (22.5 mm dia) Pilot lamp with integral circuit, terminal blo	NA	0.00	NA	0.00
	0	NA	f) An earthing terminal should be provide to the box.	f) An earthing terminal should be provide to the box.	f) An earthing terminal should be provide to the box.	NA	0.00	NA	0.00
10	0	NA	Supply and transportation of following XLPE insulated,1100V grade armoured aluminum cable as per specification confirming to IS:7098 (Part – I) **Makes:** Torent / Universal / Unicab / Havells/ Finolex / Finecab / KEI / Gloster/ Polycab /RR Kabel/ Fortune Arrt /KEC Asian Cables/Orbit/Avocab /Gemscab/Batra Henlay /Paragon.	Supply and transportation of following XLPE insulated,1100V grade armoured aluminum cable as per specification confirming to IS:7098 (Part – I) Makes: Torent / Universal / Unicab / Havells/ Finolex	Supply and transportation of following XLPE insulated,1100V grade armoured aluminum cable as per spe	NA	0.00	NA	0.00
(a)	**250**	**m**	**120 Sq.mm X 3.5 core**	**120 Sq.mm X 3.5 core**	**120 Sq.mm X 3.5 core**	**NA**	**940.31**	**RMT**	**2,35,077.50**
(b)	**150**	**m**	**95 Sq.mm X 3.5 core**	**95 Sq.mm X 3.5 core**	**95 Sq.mm X 3.5 core**	**NA**	**755.48**	**RMT**	**1,13,322.00**
(c)	**200**	**m**	**16 Sq.mm X 4 core**	**16 Sq.mm X 4 core**	**16 Sq.mm X 4 core**	**NA**	**224.22**	**RMT**	**44,844.00**
(d)	**200**	**m**	**25 Sq.mm X 3.5 core**	**25 Sq.mm X 3.5 core**	**25 Sq.mm X 3.5 core**	**NA**	**274.72**	**RMT**	**54,944.00**
11	**400**	**m**	**Laying of U.G cables from 70 Sq.mm to 150 Sq.mm through existing G.I.Pipe and back filling of trench including labour charges etc.,complete.(Excluding the cost of G.I Pipe)**	**Laying of U.G cables from 70 Sq.mm to 150 Sq.mm through existing G.I.Pipe and back filling of trench including labour charges etc.,complete.(Excluding the cost of G.I Pipe)**	**Laying of U.G cables from 70 Sq.mm to 150 Sq.mm through existing G.I.Pipe and back filling of trench**	**NA**	**114.53**	**RMT**	**45,812.00**

S.No.	Qty		Description of Item	work type (UPTO 200 characters)	Item short description (upto 100 characters)	APSS/ Morth Cl. Numb	Rate in ₹	Unit	Amount in ₹
12	**400**	**m**	**Laying of U.G cables up to 50 Sq.mm through existing G.I.Pipe and back filling of trench including labour charges etc., complete.(Excluding the cost of G.I Pipe)**	**Laying of U.G cables up to 50 Sq.mm through existing G.I.Pipe and back filling of trench including labour charges etc., complete.(Excluding the cost of G.I Pipe)**	**Laying of U.G cables up to 50 Sq.mm through existing G.I.Pipe and back filling of trench including l**	**NA**	**57.93**	**RMT**	**23,172.00**
13	0	NA	Supply and making one end termination with heavy duty single compression brass gland as per BS 6121:2005 ,IP 66 complete, SIBG type, heavy duty Aluminum lugs duly crimped with crimping tool, PVC tape etc., for following size of Armoured PVC insulated & PVC sheathed/ XLPE aluminum conductor cable of 1100 volt grade as required of size. **Makes:** Torent / Universal / Unicab / Havells/ Finolex / Finecab / KEI / Gloster/ Polycab /RR Kabel/ Fortune Arrt /KEC Asian Cables/Orbit/Avocab /Gemscab/Batra Henlay /Paragon.	Supply and making one end termination with heavy duty single compression brass gland as per BS 6121:2005 ,IP 66 complete, SIBG type, heavy duty Aluminum lugs duly crimped with crimping tool, PVC tape	Supply and making one end termination with heavy duty single compression brass gland as per BS 6121:	NA	0.00	NA	0.00
(a)	**2**	**sets**	**4 core X 6/10/16 Sqmm**	**4 core X 6/10/16 Sqmm**	**4 core X 6/10/16 Sqmm**	**NA**	**125.24**	**set**	**250.48**
(b)	**2**	**sets**	**3 core X 25 Sqmm**	**3 core X 25 Sqmm**	**3 core X 25 Sqmm**	**NA**	**146.45**	**set**	**292.90**
(c)	**2**	**sets**	**3 core X 95 Sqmm**	**3 core X 95 Sqmm**	**3 core X 95 Sqmm**	**NA**	**308.05**	**set**	**616.10**
(d)	**2**	**sets**	**3 core X 120 Sqmm**	**3 core X 120 Sqmm**	**3 core X 120 Sqmm**	**NA**	**367.64**	**set**	**735.28**
14	**200**	**Nos**	**Supply and fixing of fabricated M.S clamps made out of 25mm x 3mm MS flat with necessary holes on either side with 1 1/2" coach screws and painting 2 coats of enamel black paint over one coat of red oxide suitable for fixing of UG Cables of size 10 Sq.mm to 16 Sq.mm on walls etc. including all labour charges etc., complete.**	**Supply and fixing of fabricated M.S clamps made out of 25mm x 3mm MS flat with necessary holes on either side with 1 1/2" coach screws and painting 2 coats of enamel black paint over one coat of red o**	**Supply and fixing of fabricated M.S clamps made out of 25mm x 3mm MS flat with necessary holes on ei**	**NA**	**66.47**	**Each**	**13,294.00**
15	**200**	**Nos.**	**Supply and fixing of fabricated M.S clamps made out of 25mm x 3mm MS flat with necessary holes on either side with suitable 1 1/2" coach screws and painting 2 coats of enamel black paint over one coat of red oxide suitable for fixing of UG Cables of size 25 Sq.mm to 50 Sq.mm on walls etc., including all labour charges etc., complete.**	**Supply and fixing of fabricated M.S clamps made out of 25mm x 3mm MS flat with necessary holes on either side with suitable 1 1/2" coach screws and painting 2 coats of enamel black paint over one coat**	**Supply and fixing of fabricated M.S clamps made out of 25mm x 3mm MS flat with necessary holes on ei**	**NA**	**68.35**	**Each**	**13,670.00**
16	**300**	**m**	**Supply and Fixing of ISI Mark 25mm outer dia medium grade (1.80mm thickness) with IS:9537 part -3 P.V.C. pipe with all accessories fixing on chromium plated metallic base saddles for surface wiring on Brick / stone walls, RCC roofings,Trusses, channels including all labour charges etc., complete. (If PVC Pipes are fixed on Trusses/Channels with MS Clamps, the rate for MS Clamps will be paid Separately)**	**Supply and Fixing of ISI Mark 25mm outer dia medium grade (1.80mm thickness) with IS:9537 part -3 P.V.C. pipe with all accessories fixing on chromium plated metallic base saddles for surface wiring o**	**Supply and Fixing of ISI Mark 25mm outer dia medium grade (1.80mm thickness) with IS:9537 part -3 P**	**NA**	**133.74**	**RMT**	**40,122.00**

S.No.	Qty		Description of Item	work type (UPTO 200 characters)	Item short description (upto 100 characters)	APSS/ Morth Cl. Numb	Rate in ₹	Unit	Amount in ₹
17	**100**	**m**	**Supply and Transportation of Outer dia 160mm and inner dia 136mm double walled corrugated HDPE duct made as per specification BSEN - 500 86/IS 14930 Part-II. Makes: DURA LINE (Dura Guard) /Precision /CPE /Million(AJUSS)/ श्री Tulsii /TeleRex or any ISI make approved by CE Electrical**	**Supply and Transportation of Outer dia 160mm and inner dia 136mm double walled corrugated HDPE duct made as per specification BSEN - 500 86/IS 14930 Part-II. Makes: DURA LINE (Dura Guard) /Precisio**	**Supply and Transportation of Outer dia 160mm and inner dia 136mm double walled corrugated HDPE duc**	**NA**	**470.66**	**RMT**	**47,066.00**
18	0	NA	Supply of ……...ISI marked, PVC insulated and sheathed FRLS/FRLS-H round copper cable for voltage up to 1100V conforming to IS 694:2010. **Makes**: Finolex / RR kabel / Havells/ Finecab /KEI/Polycab/ Gloster/ Goldmedal/GM// Fortune Arrt/Anchor /Million/Sudhakar/Orbit/Batra Henlay/Salzer	Supply of ……...ISI marked, PVC insulated and sheathed FRLS/FRLS-H round copper cable for voltage up to 1100V conforming to IS 694:2010. Makes: Finolex / RR kabel / Havells/ Finecab /KEI/Polycab/ Glos	Supply of ……...ISI marked, PVC insulated and sheathed FRLS/FRLS-H round copper cable for voltage up	NA	0.00	NA	0.00
(a)	**300**	**m**	**3 core 2.5 Sq mm**	**3 core 2.5 Sq mm**	**3 core 2.5 Sq mm**	**NA**	**164.63**	**RMT**	**49,389.00**
(b)	**600**	**m**	**3 core 4.0 Sq mm**	**3 core 4.0 Sq mm**	**3 core 4.0 Sq mm**	**NA**	**230.28**	**RMT**	**1,38,168.00**
19	**20**	**Nos**	**Supply of 6 to 32A, DP MCB 10KA C/D Curve ISI Mark. Makes: Legrand-DX3 / Schneider-A9/Hager-h3/ Siemens-5SX4/ Havells STADx / Lauritz Knudsen (formerly L&T)-AU/Indo Asian-Opti pro/ HPL (Techno) /Anchor (Uno Plus)/ABB-SB200**	**Supply of 6 to 32A, DP MCB 10KA C/D Curve ISI Mark. Makes: Legrand-DX3 / Schneider-A9/Hager-h3/ Siemens-5SX4/ Havells STADx / Lauritz Knudsen (formerly L&T)-AU/Indo Asian-Opti pro/ HPL (Techno) /An**	**Supply of 6 to 32A, DP MCB 10KA C/D Curve ISI Mark. Makes: Legrand-DX3 / Schneider-A9/Hager-h3/ S**	**NA**	**698.92**	**Each**	**13,978.40**
20	0	NA	Cutting road surface including stacking of excavated materials for pipe line trench work	Cutting road surface including stacking of excavated materials for pipe line trench work	Cutting road surface including stacking of excavated materials for pipe line trench work	NA	0.00	NA	0.00
(a)	**10**	**cum**	**Cutting open Cement concrete road surface with cocrete saw cutter and removal with Breaker.**	**Cutting open Cement concrete road surface with cocrete saw cutter and removal with Breaker.**	**Cutting open Cement concrete road surface with cocrete saw cutter and removal with Breaker.**	**NA**	**5,558.06**	**cum**	**55,580.60**

S.No.	Qty		Description of Item	work type (UPTO 200 characters)	Item short description (upto 100 characters)	APSS/ Morth Cl. Numb	Rate in ₹	Unit	Amount in ₹
21	0	NA	Cement Concrete using 20 mm (0.54 cu.m) and 12 mm (0.36cu.m) nominal size hard broken granite crushed metal from any source conforming to the relevant ISI standards for foundations etc., laid in layers of not more than 15 cm thick well ompacted including curing, ,machine mixing, cost and conveyance of all materials etc., complete Note: Measurement boxes shall be used for measuring the quantities of cement, aggregate and water required for the given concrete mix.	Cement Concrete using 20 mm (0.54 cu.m) and 12 mm (0.36cu.m) nominal size hard broken granite crushed metal from any source conforming to the relevant ISI standards for foundations etc., laid in laye	Cement Concrete using 20 mm (0.54 cu.m) and 12 mm (0.36cu.m) nominal size hard broken granite crush	NA	0.00	NA	0.00
(a)	**10**	**cum**	**CC(1:3:6)**	**CC(1:3:6)**	**CC(1:3:6)**	**NA**	**6,240.45**	**cum**	**62,404.50**
22			Earthwork excavation for foundations and depositing on bank for all lifts and with an initial lead of 10m including all Operational, incidenta! ,labour charges such as shoring, sheeting, planking, strutting etc., complete for finished item of work.	Earthwork excavation for foundations and depositing on bank for all lifts and with an initial lead of 10m including all Operational, incidenta! ,labour charges such as shoring, sheeting, planking, str	Earthwork excavation for foundations and depositing on bank for all lifts and with an initial lead o	NA	0.00	NA	0.00
(a)	90	cum	Ordinary soil-Manual means up to 3m depth Note: Cost of dewtering may be added where required, up to 5% of labour cost. Assesment for dewatering shall be made as per slte condition	Ordinary soil-Manual means up to 3m depth Note: Cost of dewtering may be added where required, up to 5% of labour cost. Assesment for dewatering shall be made as per slte condition	Ordinary soil-Manual means up to 3m depth Note: Cost of dewtering may be added where required, up to	NA	343.73	cum	30,935.70
23	**20**	**m**	**Supply of Hume pipe with collar 300 mm dia.**	**Supply of Hume pipe with collar 300 mm dia.**	**Supply of Hume pipe with collar 300 mm dia.**		**584.21**	**RMT**	**11,684.20**
	0	NA	Note:	Note:	Note:	NA			0.00
	0	NA	(1) The rates quoted shall be inclusive of all other taxes and exclusive of GST	(1) The rates quoted shall be inclusive of all other taxes and exclusive of GST	(1) The rates quoted shall be inclusive of all other taxes and exclusive of GST	NA	0.00	NA	0.00
	0	NA	(2) The GST will be reimbursed as per actuals on production of proof subject to the applicable GST conditions in the tender document	(2) The GST will be reimbursed as per actuals on production of proof subject to the applicable GST conditions in the tender document	(2) The GST will be reimbursed as per actuals on production of proof subject to the applicable GST c	NA	0.00	NA	0.00
	0	NA	(3) Statutory deductions will be made as per norms, if applicable any modalities imposed of GST by the Government from time to time, the same will be implemented subject to the applicable GST conditions in the tender document	(3) Statutory deductions will be made as per norms, if applicable any modalities imposed of GST by the Government from time to time, the same will be implemented subject to the applicable GST conditio	(3) Statutory deductions will be made as per norms, if applicable any modalities imposed of GST by t	NA	0.00	NA	0.00
			Total						**54,85,139.26**
			(Rupees Fifty Four Lakh Eighty Five Thousand One Hundred Thirty Nine and Paise Twenty Six Only)						

Digitally signed by A VENKATESWARLU
Date: 23-10-2026 08:42:19