PA & VOICE EVACUATION SYSTEM SPECIFICATIONS:
1. Conforming to EN 54-16 standard with supervised amplifier channels and dual 1:1 standby auto-failover.
2. Central digital signal processor (DSP) audio matrix controller with 16 audio input buses and 32 supervised output zones.
3. Assembly Chamber and Dignitary Galleries equipped with 6W high-clarity flush ceiling speakers delivering STI > 0.65 speech intelligibility.
4. Basement parking, plant rooms, and outdoor courtyards equipped with 15W IP66 weatherproof directional horn speakers.
5. Priority 1 Fire Alarm override triggers pre-recorded phased evacuation messages in Telugu, English, and Hindi.

Audio Zone	Coverage Area	Speaker Type	Unit Power	Qty	Total Power
Zone 01	Main Assembly Chamber	Ceiling Coaxial 6W	6 Watts RMS	48 Units	288 Watts
Zone 02	Speaker's Gallery & Press	Ceiling Coaxial 6W	6 Watts RMS	24 Units	144 Watts
Zone 03	VVIP Corridors & Lobbies	Ceiling Flush 6W	6 Watts RMS	36 Units	216 Watts
Zone 04	Basement Parking Level -1	Re-entrant Horn 15W	15 Watts RMS	20 Units	300 Watts
Zone 05	Basement Parking Level -2	Re-entrant Horn 15W	15 Watts RMS	20 Units	300 Watts

AMARAVATI GOVERNMENT COMPLEX · LEGISLATIVE ASSEMBLY

DWG TITLE: PUBLIC ADDRESS & VOICE ALARM EMERGENCY RISER

DRAWING NO: SL-288-Amaravati-LA-PAVA-R1	REV: R1 ADD	SCALE: 1:100
CLIENT: AP CRDA / GOVT OF ANDHRA PRADESH	DATED: 28-09-2026	