DOMESTIC & FLUSHING WATER DISTRIBUTION RISER SPECIFICATIONS:
1. Dual-pipe distribution system separating potable domestic water from treated recycled flushing water per NBC 2016.
2. Potable Water Riser: CPVC SDR-11 piping conforming to ASTM D2846 with solvent weld joints tested to 15 kg/cm2.
3. Flushing Water Riser: UPVC Class-3 piping conforming to IS 4985 with heavy-duty solvent cement joints.
4. Pressure regulating valve (PRV) stations installed on each floor branch to ensure terminal fixture pressure between 2.0 and 2.5 bar.
5. Automatic air release valves (ARV) provided at top of each vertical riser to purge air pockets and avoid water hammer.

Riser Tag	Service	Levels Served	Riser Diameter	Design Flow	PRV Setting
RSR-DOM-01	Potable Water	Basement to Level 4 (West)	65mm CPVC	12.5 m3/hr	2.2 bar
RSR-DOM-02	Potable Water	Basement to Level 4 (East)	65mm CPVC	12.5 m3/hr	2.2 bar
RSR-DOM-03	Potable Water	Legislative Assembly Core	80mm CPVC	18.0 m3/hr	2.5 bar
RSR-FLU-01	Flushing Recycled	Basement to Level 4 (West)	80mm UPVC	16.0 m3/hr	2.0 bar
RSR-FLU-02	Flushing Recycled	Basement to Level 4 (East)	80mm UPVC	16.0 m3/hr	2.0 bar
RSR-FLU-03	Flushing Recycled	Legislative Assembly Core	100mm UPVC	24.0 m3/hr	2.2 bar

AMARAVATI GOVERNMENT COMPLEX · LEGISLATIVE ASSEMBLY		
DWG TITLE: DOMESTIC & FLUSHING WATER SUPPLY RISER DIAGRA		
DRAWING NO: SL-288-DRF-101A	REV: R1	SCALE: 1:100
CLIENT: AP CRDA / GOVT OF ANDHRA PRADESH	DATED: 28-09-2026	