FIRE FIGHTING PUMP CONTROLLER ELECTRICAL SCHEMATIC & NFPA 20 CONFORMANCE:
1. Automatic fire pump motor controller panel complying with NFPA 20 and IS 15301 standards.
2. Dual incoming power supplies: Normal utility feed from Substation + Standby feeder from Emergency DG with mechanical interlock.
3. Main Fire Pump (75 kW): Star-Delta starter with locked rotor over-current protection bypassed during emergency fire run.
4. Jockey Pump (15 kW): DOL starter with adjustable pressure switch set-points (Cut-in: 6.0 kg/cm2, Cut-out: 7.5 kg/cm2).
5. Diesel Engine Driven Standby Pump: Dual 24V DC battery sets with automatic float/boost chargers and solenoid starting valves.

Equipment Tag	Equipment Name	Capacity	Head	Starter / Drive	Feeder Cable
FP-ELEC-01	Main Electric Fire Pump	2850 LPM	88 Metres	75 kW Star-Delta	3.5C x 185 sq.mm FS
FP-DSL-01	Standby Diesel Engine Pump	2850 LPM	88 Metres	95 HP 6-Cyl Diesel	24V Dual Batteries
FP-JCK-01	System Jockey Pump	180 LPM	90 Metres	15 kW DOL Starter	3.5C x 25 sq.mm FS
FP-SPR-01	Main Sprinkler Electric Pump	2850 LPM	88 Metres	75 kW Star-Delta	3.5C x 185 sq.mm FS

AMARAVATI GOVERNMENT COMPLEX · LEGISLATIVE ASSEMBLY

DWG TITLE: FIRE HYDRANT, SPRINKLER & JOCKEY PUMP CONTROL

DRAWING NO: SL-288-EL0-057 - SINGLE LINE S	REV: R1	SCALE: 1:100
CLIENT: AP CRDA / GOVT OF ANDHRA PRADESH	DATED: 28-09-2026	