Tender ID: 996686 | Notice Ref: 21/MD/CE(ELE)AGICL/2026, Dt.28.09.2026
ECV: Rs. 3,37,90,33,865/- | Closing Date: 30-10-2026 03:00 PM
File: SL-288-LA_HVAC_TECHNICAL__SPECIFICATION-15.04.2026.pdf

HVAC SYSTEM ENGINEERING SPECIFICATIONS & PERFORMANCE CRITERIA

1. Water-Cooled Centrifugal Chiller Plant:
   ? 3 Nos. 800 TR + 1 No. 400 TR Variable Speed Drive (VSD) water-cooled centrifugal chillers.
   ? Eco-friendly low GWP refrigerant (R-1233zd(E) / R-514A).
   ? Integrated Part Load Value (IPLV) not exceeding 0.35 kW/TR.

2. Air Handling Units (AHU) & Air Distribution:
   ? Double-skin thermal-break AHUs with EC plug fans conforming to Eurovent / AHRI 410.
   ? Factory-fabricated pre-insulated PIR / GI spiral ductwork conforming to SMACNA Class 3.
   ? Variable Air Volume (VAV) terminal units with BACnet DDC controllers.