Tender ID: 996686 | Notice Ref: 21/MD/CE(ELE)AGICL/2026, Dt.28.09.2026
ECV: Rs. 3,37,90,33,865/- | Closing Date: 30-10-2026 03:00 PM
File: SL-288_Assembly_Building_fire_fighting_technical_specification-13.04.2026.pdf

FIRE PROTECTION, DETECTION & SUPPRESSION SYSTEM SPECIFICATIONS

1. Fire Hydrant & Automatic Sprinkler System:
   ? Conforming strictly to NBC 2016 Part 4 and NFPA 13 & 14 standards.
   ? Main Fire Pumps: 2850 LPM @ 12.0 Bar Electric Motor Driven + Standby Diesel Engine Driven Pump.
   ? Quick-response pendant and upright brass sprinkler heads (68°C glass bulb rating).

2. Clean Agent Gas Fire Suppression for Data Center & Server Rooms:
   ? Novec 1230 / FK-5-1-12 total flooding fire suppression system adhering to NFPA 2001.
   ? Zero Ozone Depletion Potential (ODP) and negligible atmospheric lifetime.