ANDHRA PRADESH POWER GENERATION CORPORATION LTD
Dr. NARLA TATA RAO THERMAL POWER STATION O & M
VIJAYAWADA - 521456

From :
Chief Engineer
O&M,Dr.NTTPS
Ibrahimpatnam-521456
Krishna(Dt)
Andhrapradesh
Phone :08662882614 Fax:08662882365

GST No.: 37AACCA2734J1ZR

To :
AP E-Procurement

Enquiry No: M100031852/CE/O&M/SE(A&MM)/DE/PUR I/ V02 / 26-27 Dt:21.10.2026

Sub: DR. NTTPS -BM-STG-III- PROCUREMENT OF PRESSURE PARTS CDS TUBES OF UNITS-5&6 BOILERS-REG

Sir,

Ref: T No.M100031852/P111/ Supply of CDS Tubes, Stg 3
Technical Bid Due date: 1 1 .11.2026; Time: 10:30 Hours
Price Bid Due date:12.11.2026; Time: 11:00 Hours

Please furnish your offer for the materials indicated in the enclosed bill of material and furnish your offer through ap e-procurement on the website https://tender.apeprocurement.gov.in before schedule dates mentioned in the NIT (Notice inviting tender).
You are requested to prepare the technical bid along with the detailed specification on your letter head and arrange to upload the same in the website for our verification. Also it is requested to sign on our specification and upload the same and mention the deviations if any.
Offer shall be submitted along with Earnest Money Deposit of 0.5% of quoted value as per the Payment options available in the E-procurement platform. Please furnish copy of price list and recently executed orders in support of your quoted prices for our reference and also furnish your GST & PAN number along with your offer.
PEMD/SSI/NSIC Units etc. shall furnish documentary evidence (Indicated with Certificated number) along with your offer for exempting the EMD.
You are further advised to go through carefully the enclosed documents and furnish the offer strictly as per given instructions otherwise your offer shall be ignored.

Note:

1. Bidders must be a Manufacturer/Supplier. In case of supplier, Authorization certificate of recent period shall be furnished.
2. Please furnish copy of New Price List and recently executed orders in support of your quoted prices for our reference and also indicate your TIN, GST & PAN numbers.
3. Please furnish HSN codes of the quoted items and corresponding GST applicable.
4. Bidders should upload the documents as mentioned in NIT

SD/-XXX
Chief Engineer/O&M/Dr.NTTPS

Enclosures:
1) Bill of Materials.
2) Annexure-II (APGENCO Terms and Conditions)
3) 3)Instructions to Bidders.
4) General Purchase conditions
5) NIT
6) Deviation
7) 3No' s Technical Specifications
i) Doc.No.APG-LAS & SS Tubes Dt:18.10.2022 Rev.0 for items no:01 to 06.
ii) Doc.No.APG-AS Tubes Dt:25.10.2022 Rev.0 for items No: 07,10,11,13,15 &16.
iii) Doc.No.APG-CS Tubes Dt:19.10.2022 Rev.0 for items No: 08,09,12 &14.

Annexure-I

Enquiry No : M100031852 Dated : 21.10.2026

Sr No:	Material Code / Material Description	HSN Code	UOM	Quantity	Quoted Price	Total Value
1	100114514 ITSH TUBE OD:38 MM, THICKNESS:4.0 MM. MATERIAL:SA213TP347H Operang Pressure- 161.2 Kg/cm2, Operang Temperature - 528 deg C, Hydro stac pressure -241.8 Kg/cm2.	7304	M	250.000		
2	100163808 HTSH TUBE OD:44.5 MM, THICKNESS:5.0 MM. MATERIAL:SA213TP347H Operating Pressure- 158.6 Kg/cm2, Operating Temperature - 563 deg C, Hydro static pressure -237.9 Kg/cm2.	7304	M	150.000		
3	100059253 HTSH TUBE OD:44.5 MM, THICKNESS:4.0 MM. MATERIAL:SA213TP347H Operating Pressure- 158.6 Kg/cm2, Operating Temperature - 563 deg C, Hydro static pressure -237.9 Kg/cm2.	8402	M	150.000		
4	100140900 HTSH TUBE OD:44.5 MM, THICKNESS:5.6 MM. MATERIAL:SA213T22 Operating Pressure- 158.6 Kg/cm2, Operating Temperature - 563 deg C, Hydro static pressure -237.9 Kg/cm2.	8402	M	100.000		
5	100035904 HTRH TUBE OD:51MM, THICKNESS:3.6 MM. MATERIAL:SA213TP347H Operating Pressure- 39.2 Kg/cm2, Operating Temperature - 579 deg C, Hydro static pressure -100 Kg/cm2.	7304	M	150.000		
6	100066414 HTRH TUBE OD:51MM, THICKNESS:3.6 MM. MATERIAL:SA213T22 Operating Pressure- 39.2 Kg/cm2, Operating Temperature - 579 deg C, Hydro static pressure -100 Kg/cm2.	7304	M	200.000		
7	100011092 HANGER PLATEN TUBE OD:44.5 MM, THICKNESS:6.3 MM. MATERIAL: SA213T11 Operating Pressure- 170 Kg/cm2, Operating Temperature - 402 deg C, Hydro static pressure -255 Kg/cm2.	7304	M	200.000		
8	100105047 TUBE; OUTSIDE DIAMETER:44.5MM; THICKNESS:4.5 MM; MATERIAL:SA210 GR. A1 Operating Pressure- 172.4 Kg/cm2, Operating Temperature - 302 deg C, Hydro static pressure -258.6 Kg/cm2.	7304	M	300.000		
9	100039098 WATER WALL TUBE OD:63.5 MM, THICKNESS:5.6 MM. MATERIAL: SA210GR.A1. Operating Pressure- 184.5 Kg/cm2, Operating Temperature - 350 deg C,	7304	M	800.000		

Sr No:	Material Code / Material Description	HSN Code	UOM	Quantity	Quoted Price	Total Value
	Hydro static pressure -276.75 Kg/cm2.					
10	100163865 LTRH TUBE OD:54 MM, THICKNESS:3.6MM. MATERIAL:SA209T1 Operating Pressure- 39.8 Kg/cm2, Operating Temperature - 579 deg C, Hydro static pressure -100 Kg/cm2.		M	150.000		
11	100105057 LTRH TUBE OD:54 MM, THICKNESS:3.6MM. MATERIAL:SA213T11 Operating Pressure Pressure- 39.8 Kg/cm2, Operating Pressure Temperature - 579 deg C, Hydro static pressure - 100 Kg/cm2.	7304	M	200.000		
12	100105050 LTRH TUBE OD:54 MM, THICKNESS:3.6MM. MATERIAL: SA210Gr.A1 Operating Pressure- 39.8 Kg/cm2, Operating Temperature - 579 deg C, Hydro static pressure -100 Kg/cm2	7304	M	350.000		
13	100105052 LTSH TUBE OD:44.5 MM, THICKNESS:4.0MM. MATERIAL:SA213T11 Operating Pressure- 164.5 Kg/cm2, Operating Temperature - 449 deg C, Hydro static pressure -250 Kg/cm2.		M	100.000		
14	100033752 LTRH INLET SWAGED TUBES OD 44.5MMXThickness 4.5MM(Material.SA210Gr.A1) and OD 54MMXThickness 3.6MM (Material.SA210Gr.A1) Operating Pressure- 39.8 Kg/cm2, Operating Temperature - 579 deg C, Hydro static pressure -100 Kg/cm2		NO	50.000		
15	100058896 LTRH OUTLET SWAGED TUBES OD44.5MMXThickness4.5MM (Material.SA213T11) and OD54MMXThickness3.6MM (Material.SA213T11) Operating Pressure- 39.8 Kg/cm2, Operating Temperature - 579 deg C, Hydro static pressure -100 Kg/cm2.		NO	50.000		
16	100105051 LTSH TUBE OD:44.5 MM, THICKNESS:4.5MM. MATERIAL:SA209T1 Operating Pressure- 164.5 Kg/cm2, Operating Temperature - 449 deg C, Hydro static pressure -250 Kg/cm2	7304	M	150.000		

SD/-XXX

Chief Engineer/O&M/Dr.NTTPS

