



# CHAPTER 11: DIGITAL CONTROL



**When I complete this chapter, I want to be able to do the following.**

- **Identify examples of analog and digital computation and signal transmission.**
- **Program a digital PID calculation**
- **Select a proper execution rate for a feedback controller.**
- **Tune a digital PID**

# CHAPTER 11: DIGITAL CONTROL



**Outline of the lesson.**

- **Brief history of control equipment**
- **Sampling the measurement**
- **Digital PID calculation**
- **Effect of digital execution period on tuning and performance**

# CHAPTER 11: DIGITAL CONTROL


## A BRIEF HISTORY OF PROCESS CONTROL

- **A little history helps us to understand the common approaches to process control. The realities of available equipment have shaped the theory and practice of process control.**
- **While digital technology has revolutionized what is possible today, equipment has a life of many decades. Therefore, we see older approaches in most plants, and will for a long time.**
- **Let's start from about the 19th century to today. What happened in the 19th century that “got things going”?**

# CHAPTER 11: DIGITAL CONTROL

## Making the steam engine work all the time

governor



Inventors wanted to control the pressure of the boiler and the speed of the device driven by the steam (using a governor).

People experienced

- Explosions!
- Unstable behavior


And control engineering was born!

# CHAPTER 11: DIGITAL CONTROL

## Manual Operation

**People know more than machines, so leave decisions to them.**

- Manual operation
- Mechanical devices
- Pneumatic devices
- Electronic devices
- Digital calculations
- Digital calc. & communication



# CHAPTER 11: DIGITAL CONTROL


## Mechanical Device

The value of the variable is represented by position of equipment.

- Manual operation
- Mechanical devices
- Pneumatic devices
- Electronic devices
- Digital calculations
- Digital calc. & communication



How do I change the set point?




# CHAPTER 11: DIGITAL CONTROL

## Pneumatic Device

The value of the variable is proportional to air pressure (50 - 150 C = 3 -15 psi).

- Manual operation
- Mechanical devices
- Pneumatic devices
- Electronic devices
- Digital calculations
- Digital calc. & communication



The signal is 3-15 psi air pressure in a pipe.

Air pressure moves flexible diaphragm

How do I perform the PID calculation?



# CHAPTER 11: DIGITAL CONTROL

## Pneumatic & Electronic Devices

### Principle of analog computation!

$$MV(t) = K_c \left[ E(t) + \frac{1}{T_I} \int_0^t E(t') dt' + T_d \frac{d E(t)}{dt} \right] + I$$

**Build a physical system that (approximately) obeys the same model.**

- **Pneumatic - force balance (Newton's laws)**
- **Electronic - current balance (Kirkoff's laws)**



**I wonder what these devices look like.**

- **Manual operation**
- **Mechanical devices**
- **Pneumatic devices**
- **Electronic devices**
- **Digital calculations**
- **Digital calc. & communication**



# CHAPTER 11: DIGITAL CONTROL

## Analog computation!

$$MV(t) = K_c \left[ E(t) + \frac{1}{T_I} \int_0^t E(t') dt' + T_d \frac{dE(t)}{dt} \right] + I$$

### Pneumatic




FIGURE 6-9 Three-mode controller with parallel feedback.

### Electronic





FIGURE 6-15 Simplified diagram of Taylor Transcope electronic controller, model 70RF.

# CHAPTER 11: DIGITAL CONTROL

- Manual operation
- Mechanical devices
- Pneumatic devices
- Electronic devices
- Digital calculations
- Digital calc. & communication

## Electronic Device

The variable is proportional to current or voltage ( $50 - 150\text{ C} = 4 - 20\text{ mA}$ ).



The signal is 4-20 mA transmitted by wire.

Current converted to air pressure to affect valve

I'll use analog computation again.




# CHAPTER 11: DIGITAL CONTROL

- Manual operation
- Mechanical devices
- Pneumatic devices
- Electronic devices
- Digital calculations
- Digital calc. & communication

## Digital Calculation

**Digital calculations with electronic transmission.**



**We'll soon see how to calculate PID digitally.**




# CHAPTER 11: DIGITAL CONTROL

## Digital Calculation & Communication

Digital calculations with transmission by local area network. **Sensor and valve can have microprocessors too!**

- Manual operation
- Mechanical devices
- Pneumatic devices
- Electronic devices
- Digital calculations

- Digital calc. & communication



We soon see how to calculate PID digitally.




The signal transmitted digitally.

converted to air pressure to affect valve

# CHAPTER 11: DIGITAL CONTROL

Digital control employs a distributed computing network




# CHAPTER 11: DIGITAL CONTROL

**Digital control employs a distributed computing network**

Feature	Effect on process control
Calculations performed in parallel by numerous processors	Control calculations are performed faster than if by one processor
Limited number of controller calculations performed by a single processor	Control system is more reliable since a processor failure affects only few control loops
Control calculations and interfacing to process independent of other devices connected to the LAN	Control is more reliable since failure of other devices does not immediately affect a control processor
Small amount of equipment required for the minimum system	Only the equipment required must be purchased, and the system is easily expanded at low cost
Each type of processor can have different hardware and software	Hardware and software can be tailored to specific applications like control, monitoring, operator console, and general data processing

# CHAPTER 11: DIGITAL CONTROL


**Let's remember that control is performed many places; locally and remotely by people and equipment.**



**FIGURE 1.6**

# CHAPTER 11: DIGITAL CONTROL

A rough indication of the use of various devices for control calculations for new industrial process control systems.





# CHAPTER 11: DIGITAL CONTROL


- Manual operation
- Mechanical devices
- Pneumatic devices
- Electronic devices

- Digital calculations
- Digital calc. & communication


**The techniques presented will be applicable for digital sampling and calculation.**

**Transmission can be electronic or digital.**


**Periodically, the measurement is sampled and a calculation is performed.**





# CHAPTER 11: DIGITAL CONTROL




Continuous signal



Fast sampling



Slow sampling






# CHAPTER 11: DIGITAL CONTROL


**Aliasing:** Sampling much slower than the measurement changes causes significant loss of information.

Engineer should design for sampling “fast enough”.

Continuous signal




Slow sampling




# CHAPTER 11: DIGITAL CONTROL

We “hold” the last sampled value between control executions.



# CHAPTER 11: DIGITAL CONTROL

The **red line** is the continuous approximation of the signal after the sample & hold. This shows that the effect is to introduce a “dead time” of about  $\Delta t/2$ .




# CHAPTER 11: DIGITAL CONTROL

$$MV(t) = K_c \left[ E(t) + \frac{1}{T_I} \int_0^t E(t') dt' - T_d \frac{d CV(t)}{dt} \right] + I$$

We have a sample of values;  $CV_1, CV_2, \dots, CV_N$

**Proportional:**

**Integral:**



**Hint: How would you estimate  
each mode using numerical  
methods?**

**Derivative:**

# CHAPTER 11: DIGITAL CONTROL

$$MV(t) = K_c \left[ E(t) + \frac{1}{T_I} \int_0^t E(t') dt' - T_d \frac{d CV(t)}{dt} \right] + I$$

We have a sample of values;  $CV_1, CV_2, \dots, CV_N$

**Proportional:**



$$E_N = SP_N - CV_N$$

$$(MV_N)_{proportional} = K_C E_N$$

**Integral:**



Calculated every time the controller is executed.

**Derivative:**

# CHAPTER 11: DIGITAL CONTROL

$$MV(t) = K_c \left[ E(t) + \frac{1}{T_I} \int_0^t E(t') dt' - T_d \frac{d CV(t)}{dt} \right] + I$$

We have a sample of values;  $CV_1, CV_2, \dots, CV_N$

**Proportional:**

$$E_N = SP_N - CV_N$$

$$(MV_N)_{\text{integral}} = \frac{K_C (\Delta t)}{T_I} \sum_{i=1}^N E_i$$

**Integral:**



Calculated every time the controller is executed.

- $\Delta t = \text{constant}$
- How many elements in sum?

**Derivative:**



# CHAPTER 11: DIGITAL CONTROL

$$MV(t) = K_c \left[ E(t) + \frac{1}{T_I} \int_0^t E(t') dt' - T_d \frac{d CV(t)}{dt} \right] + I$$

We have a sample of values;  $CV_1, CV_2, \dots, CV_N$

**Proportional:**

$$E_N = SP_N - CV_N$$

$$SUM_N = SUM_{N-1} + E_N$$

**Integral:**

$$(MV_N)_{\text{integral}} = \frac{K_C(\Delta t)}{T_I} (SUM_N)$$



**Efficient calculation in realtime!**

**Derivative:**

# CHAPTER 11: DIGITAL CONTROL

$$MV(t) = K_c \left[ E(t) + \frac{1}{T_I} \int_0^t E(t') dt' - T_d \frac{d CV(t)}{dt} \right] + I$$

We have a sample of values;  $CV_1, CV_2, \dots, CV_N$

**Proportional:**

**Integral:**

$$(MV_N)_{derivative} = -K_C T_d \frac{(CV_N - CV_{N-1})}{\Delta t}$$



Calculated every time the controller is executed.

**Derivative:**

## CHAPTER 11: DIGITAL CONTROL

$$MV(t) = K_c \left[ E(t) + \frac{1}{T_I} \int_0^t E(t') dt' - T_d \frac{d CV(t)}{dt} \right] + I$$

We have a sample of values;  $CV_1, CV_2, \dots, CV_N$

$$I = MV_1 - K_c \left[ E_1 - T_d \frac{(CV_1 - CV_0)}{\Delta t} \right]$$

“I” is  
sometimes  
called the bias.



Calculated only when  
the controller is turned on,  $N=1$ .  
**Thereafter, I is constant**

**Bumpless transfer:** No change to the MV  
when controller is first executed

## CHAPTER 11: DIGITAL CONTROL

$$MV(t) = K_c \left[ E(t) + \frac{1}{T_I} \int_0^t E(t') dt' - T_d \frac{d CV(t)}{dt} \right] + I$$

**Digital PID, positional form** calculates the output to the final element

$$MV_N = K_c \left[ E_N + \frac{\Delta t}{T_I} \sum_{i=1}^N E_i - \frac{T_d}{\Delta t} (CV_N - CV_{N-1}) \right] + I$$



**Put all modes together.**

## CHAPTER 11: DIGITAL CONTROL


$$MV_N = K_c \left[ E_N + \frac{\Delta t}{T_I} \sum_{i=1}^N E_i - \frac{T_d}{\Delta t} (CV_N - CV_{N-1}) \right] + I$$

**Digital PID, Velocity form** - Alternatively, we can calculate the change in the signal at every execution.





$$\Delta MV_N = K_c \left[ E_N - E_{N-1} + \frac{(\Delta t)}{T_I} E_N - \frac{T_d}{\Delta t} (CV_N - 2CV_{N-1} + CV_{N-2}) \right]$$
$$MV_N = MV_{N-1} + \Delta MV_N$$

# CHAPTER 11: DIGITAL CONTROL

**What is the effect of digital execution of the PID controller on tuning and performance?**





# CHAPTER 11: DIGITAL CONTROL



**CONCLUSION: We should retune the controller when the execution is slow compared with the feedback dynamics!**

# CHAPTER 11: DIGITAL CONTROL



**Guideline** for selecting the execution time:

To prevent degradation of control loop performance, select a controller execution time of  $\Delta t \leq 0.05(\theta + \tau)$ .


**Note:** Typical sample period for chemical process control is 1/3-1/2 second. Much faster is possible, if needed.



# CHAPTER 11: DIGITAL CONTROL

**Modified PID tuning for digital controllers - this is a guideline that usually works adequately.**


**We learned that sampling introduces an additional dead time of about  $\Delta t/2$ .**



1. Obtain model, usually using empirical method
2. Determine the sample period,  $\Delta t \leq 0.05(\theta + \tau)$ , if possible
3. Recalculate the dead time as  $\theta' = \theta + \Delta t/2$
4. Calculate tuning using continuous method
5. Implement and fine tune as needed

# CHAPTER 11: DIGITAL CONTROL

Let's apply this guideline for the three-tank mixer with a long sample time = 15 minutes.




## Process reaction curve

$$K_p = 0.039 \%A/\%open$$

$$\theta = 5.5 + ?? = ?? \text{ min}$$

$$\tau = 10.5 \text{ min}$$



## Tuning from chart

$$K_c = ??$$

$$T_I = ??$$

$$T_d = ??$$

# CHAPTER 11: DIGITAL CONTROL

**The performance is about as good as possible with this very long sampling time! Would you fine tune further?**


## Tuning from chart

$$K_c = 20$$

$$T_I = 14$$


$$T_d = 2.35$$

**IAE increased  
from 12.2 to 20+**



# CHAPTER 11: DIGITAL CONTROL


**If the PID is no better in digital form, why did we spend decades of engineering time and billions of dollars converting the world's control to digital?**



**FIGURE 1.6**

# CHAPTER 11: DIGITAL CONTROL

Why did we convert the world's control to digital - **Complex controllers**



**Improved performance** can be achieved with algorithms that **optimize the path** to the set point, every controller execution!

(See Chapters 19 and 23)

# CHAPTER 11: DIGITAL CONTROL

**Why did we convert the world's control to digital - Process monitoring**




**We have a digital history of measurements for**

- **Recall at any time for trouble shooting**
- **Calculation of process performance indicators, heat transfer coefficients, reactor yields, energy/kg of product, and so forth**
- **Excellent graphical displays with data in context of process schematic**

**(See Chapter 26)**

# CHAPTER 11: DIGITAL CONTROL

Why did we convert the world's control to digital - **Process optimization**



(See Chapter 26)

# CHAPTER 11: DIGITAL CONTROL

**Why did we convert the world's control to digital -Diagnostics**



**We have digital monitors at sensor, controller and valve!**

- **Compare signal to valve with actual valve position - report significant errors**
- **Diagnose problems with sensor (voltage, etc.)**
- **Do not take feedback control action on questionable loop - alarm operator**

**And many other reasons that digital is a winner.**





## **CHAPTER 11: DIGITAL CONTROL, WORKSHOP 1**

**1. Select all of the appropriate answers. Mechanical implementation of feedback control employs**

- a. Digital computation**
- b. Analog computation**
- c. Neither a nor b**
- d. Both a and b**

**2. A digital PID controller is operating “in automatic”, i.e., it is calculating the signal to the final element. You are fine tuning the loop. You change the controller gain by -30% of its original value.**

**Describe what happens.**


## CHAPTER 11: DIGITAL CONTROL, WORKSHOP 2

You are tuning the temperature controller shown in the figure. You have determined the dynamic model below.

Determine the PID tuning for this loop for execution periods below and simulate the results using S\_LOOP.

- $\Delta t = 0.10$
- $\Delta t = 1.0$
- $\Delta t = 5.0$

(All times are in minutes.)




$$G_P(s) = \frac{T(s)}{v_2(s)} = \frac{-.53e^{-0.20s}}{10s + 1}$$

## CHAPTER 11: DIGITAL CONTROL, WORKSHOP 3

**Develop a table with advantages and disadvantages for the six control equipment categories for many important issues.**

	reliability	speed	Many more!!
Manual operation			
Mechanical devices			
Pneumatic devices			
Electronic devices			
Digital calculations			
Digital calcs. & communication			

# CHAPTER 11: DIGITAL CONTROL



**When I complete this chapter, I want to be able to do the following.**

- **Identify examples of analog and digital computation and signal transmission.**
- **Program a digital PID calculation**
- **Select a proper execution rate for a feedback controller.**
- **Tune a digital PID**



**Lot's of improvement, but we need some more study!**

- **Read the textbook**
- **Review the notes, especially learning goals and workshop**
- **Try out the self-study suggestions**
- **Naturally, we'll have an assignment!**

# **CHAPTER 11: LEARNING RESOURCES**

- **SITE PC-EDUCATION WEB**
  - **Instrumentation Notes**
  - **Interactive Learning Module (Chapter 11)**
  - **Tutorials (Chapter 11)**
- **Software Laboratory, S\_LOOP**
  - **You can simulate a PID loop with continuous of digital control to determine the effect of execution period.**

## **CHAPTER 11: SUGGESTIONS FOR SELF-STUDY**

- 1. Find some process reaction curve plots in Chapters 3-5. Determine the maximum PID execution period. Then, for a controller execution period ten times the minimum, determine the tuning for PID and PI controllers using the tuning charts.**
- 2. Using S\_LOOP, simulate the system(s) in question 1.**
- 3. Develop a flowchart for an excellent computer program to calculate the PID control. This should be a subroutine that can be called for every controller in the plant.**

## **CHAPTER 11: SUGGESTIONS FOR SELF-STUDY**

- 4. Take an inventory of your house and identify analog and digital control systems.**
- 5. Develop a simulation that accepts a continuous signal and determines the output of a zero-order hold and first-order hold.**