

Taylor Consulting Group, LLC
PO Box 1570
Mentor, OH 44061

Phone: 440-840-9019
Fax: 440-209-9841
Email: gtaylor@tcgroupdesign.com



October 29, 2021

Mr. Chris Coad
Director of Business Services
Brecksville-Broadview Heights City School District
6638 Mill Road
Brecksville, OH 44141

RE: 2022 Roof Replacement Project
High School (Roof Sections 1, 3, & 4)

Dear Mr. Coad:

Enclosed please find a bid evaluation report and recommendation for Brecksville-Broadview Heights City School District, 2022 Roof Replacement Project, High School (Roof Sections 1, 3, & 4).

Should you require clarification or need additional information, please contact me at your earliest convenience.

Sincerely,

A handwritten signature in black ink, appearing to read "Gregory R. Taylor", written over a light gray rectangular background.

Gregory R. Taylor, RRC

GRT/ct

Enclosure

BID EVALUATION REPORT & RECOMMENDATION

PROJECT: Brecksville-Broadview Heights City School District
2022 Roof Replacement Project
High School (Roof Sections 1, 3, & 4)

BID OPENING: October 29, 2021, 12:00 p.m.

A total of six bids were received for the Brecksville-Broadview Heights City School District, High School Roof Replacement Project. The bidding range was \$517,800.00 to \$879,400.00. The low bid of \$517,800.00 is within range of the estimated project construction budget of \$821,286.00 and was submitted by Warren Roofing & Insulating Company.

My recommendation is to award a contract to Warren Roofing & Insulating Company for Base Bid Item 1: High School Roof Replacement (Roof Sections 1, 3, & 4)-Fully Adhered 60 mil EPDM, in the amount of \$517,800.00.

Warren Roofing & Insulating Company

Item 1	Base Bid Prime Contract-General Construction: High School Roof Replacement (Roof Sections 1, 3, & 4)	\$517,800.00
---------------	--	---------------------

TOTAL CONTRACT: \$517,800.00

I have interviewed John Arsena, Vice President, Warren Roofing & Insulating Company. I requested verification he has examined and carefully studied the Contract Documents and other related data identified in the Bidding Documents. I also discussed, and verified, he does not consider further examinations, investigations, explorations, test, studies, and data are necessary for the performance of the Work at the Contract Price, within the contract times, and in accordance with the other terms and conditions of the contract Documents.

Mr. Arsena confirmed there were no conflicts, errors, ambiguities, or discrepancies discovered in the Contract Documents. The Contract Documents are generally sufficient to indicate and convey understanding of all terms and conditions for performance and furnishing of the Work.

UNIT COST ITEMS:

The add/deduct unit costs for each bid item listed below provide flexibility during the construction phase of this project, to either direct the Contractor to perform additional work items with predetermined fixed costs that are captured in the competitive environment, or to complete less work than the base bid allowances and provide a cost credit.

Base Bid Item 1: Roof Replacement – High School (Roof Sections 1, 3, & 4)
Division 7-Thermal & Moisture Protection (07530-Fully-Adhered 60 mil EPDM)

Description	Estimated Quantity	Unit Price	/	Unit of Measure	Extension
Masonry repairs, cleaning and water repellants. Requires proposal plus 15%.	1 EA	<u>Lump Sum</u>	/	Lump Sum	<u>\$5,000.00</u>
Replacement of deteriorated 2" x 8" wood nailers matching the configuration of existing wood nailers.	800 LF	<u>\$ 5.00</u>	/	Lineal Foot	<u>\$4,000.00</u>
Replacement of deteriorated existing roof drains with new 4" cast roof drains including Insulated leaders tied into existing leaders.	1 Each	<u>\$ 1,500.00</u>	/	Total 2 Each	<u>\$3,000.00</u>
Securement of existing loose wood nailers with mechanical fasteners (staggered 6" oc.).	600 LF	<u>\$ 2.00</u>	/	Lineal Foot	<u>\$1,200.00</u>
Installation of walkway pads.	50 LF	<u>\$ 30.00</u>	/	Lineal Foot	<u>\$1,500.00</u>
Material price surcharge allowance – contractor is required to produce bidding Quote and purchase invoice.	1 Each	<u>Lump Sum</u>	/	Lump Sum	<u>\$38,000.00</u>
SUBTOTAL OF UNIT PRICE EXTENSIONS:					<u>\$52,700.00</u>