
Control

for a certain process(plant) there is an input and an output. control is the process of making a system variable adhere to a particular value, the reference value.

open-loop: system does not measure output, and there is no compensation of that output to make it conform to the desired output.

Closed-loop: System uses feed back, which is measuring a control variable and returning the output to influence the value of the variable.



system errors can be made less sensitive with feedback than they are in open loop systems by a factor of I+AK

Sensitivity to gain changes:

$$\frac{gy}{y} = S \frac{SA}{A}$$

Where S is the sensitivity. good if it's small.

for open-loop (o.L.):

$$\frac{\delta y_{oL}}{y_{oL}} = \frac{\delta A}{A} \qquad S = 1$$

for closed-loop (C.L.)

$$\frac{\delta y_{CL}}{y_{GL}} = \frac{1}{1+AK} \frac{\delta A}{A}$$

since Ak is large (usually), sensitivity decreases to variations in plant gain A.

proportional feedback

feedback control signal is made to be linearly proportional to the error in the measured output

$$\frac{U(s)}{F(s)} = D(s) = K$$

(La Place transform stuff to get to s-plane) D(S) is the controller transfer fon.

Proportional controller can be viewed as an amplifier with a "knob" to adjust the gain up or down.

advantages: reduces error responses to disturbances Character Control of the

increases speed of response

disadvantages: still allows for a non-zero steady-state error has large transient overshoot


may have a steady-state offset (choop) in response to

a constant reference input may not be entirely capable of rejecting a constant disturbina for higher order systems, large values of the proportional feedback gain will typically lead to instability.

large K reduces errors, but leads to decreased damping ratio (more overshoot) There is a limit on how much the errors can be reduced with P only.

Integral Control:

$$u(t) = \frac{K}{T_{z}} \int_{t_{0}}^{t} e(\eta) d\eta$$



$$D(s) = \frac{k}{\tau_{r} s}$$

(LaPlace Transform)

 T_{z} is the integral or reset time.

 \overline{T}_{z} is a measure of the speed of the response and is the reset rate.

but, very small damping ratio - response become oscillatory response slows down, stability is decreased.

$$\frac{PI}{E}: u(t) = K \left[r - y + \frac{1}{E} \int_0^t (r - y) d\eta \right]$$

by choosing K and Tz, the designer can independently control certain coefficients (doesn't really mean anything to bs.)

=> result is better transient response and greater reduction of emots.


Derivative feedback:

proportional to the rate of enor-no good for steady-state enors! u(t) = KTD e(t)

$$D(s) = kT_D S$$

To is called derivative time damping is increased (faster response) stability is improved.

but can't be used alone. exhibits an anticipatory response (faster) PID



linear combination of most controls proportional to error, time integral of error, and time rate of change of error

good error reduction with good stability and damping.

$$D(s) = K\left(1 + \frac{1}{T_E s} + T_D s\right) \qquad u(t) = K\left[e(t) + \frac{1}{T_E} \int_0^t e(\eta) d\eta + T_D \dot{e}(t)\right]$$


adjusting K. Tz, Tp is called tuning the controller

K1, 1 => errors 1, stability 1

To 1, -> stability 1

Ubiquitous in the process-control industry and is the basic ingredient in many control systems.

feed-forward



put sensor right after load (before plant).

improved performance can be obtained if this information is

fed forward to the controller

good for chemical processes—can change a conditions in

response to feed conditions