

Ticket #1331

Ticket Status: Closed

Name: Philip Piper

Department: Electrical

Email: piper.m.philip@gmail.com

Create Date: 04/14/2016 6:54 pm

Phone: (713) 501-2744

Field of Study: Electrical Engineering

Subject: **Yale University**

04/14/2016 6:54 pm Philip Piper

We will be running shielded cable to Amphenol PowerLok 1 and 3 conductor connectors. Are the PowerLok connectors considered adequate strain relief or do we need to implement additional measures?

Best,

Phil

04/15/2016 12:50 pm

Yes Phil - they powerlok connectors are rated for adequate strain relief

Please Wait!

Please wait... it will take a second!