

If a 1PH (single phase) or 3PH (3 phase) job is booked in but it is determined to be raised incorrectly (ie. raised as 1PH but 3PH on site, etc) the information below can be used to determine if the job can go ahead.

1PH booked but 3PH on site -> Eligible to complete, subject to skill-set of engineer and eligible for install & leave, subject to standard commissioning policy/validation

3PH booked but 1PH on site -> Eligible to complete and eligible for install & leave, subject to standard commissioning policy/validation

1PH ALCS but 3PH ALCS to be installed -> Eligible to complete, subject to skill-set of engineer but should it fail to commission - **it must be an abort**

3PH ALCS but 1PH ALCS to be installed -> Eligible to complete and eligible for install & leave, subject to standard commissioning policy/validation

Additional Notes:

- If ALCS job raised, but **NO** ALCS required, fit 5T (5 Terminal), bung the 5th terminal
- If **Non-ALCS** job raised but **ALCS required**- job must be **aborted** with code from TL for wrong job type raised