

Installation Policy & Exceptions (Dec 2025 Update)

As of December 2025, the standard policy is **Install & Leave** or **Install, Join & Leave**. However, two specific job types are **NON-ELIGIBLE** for this and must be fully commissioned **BEFORE** an engineer leaves the site. Below is information about how to Identify and handle 3PH ALCS and Economy 2000 (ECO 2000) jobs.

The "Non-Eligible" Exceptions

If the job is one of the following, you **MUST** receive a **COMP-FULL** status.

Job Type	How to Identify
ECO 2000	Check the heating type. It won't be on the job card. Look for " Group Code 20 " sticker on the RTS or old meter photos. If Group Code sticker missing number, check Campaign ID under Customer Details page on jobcard or on Enduring.
3PH ALCS	Check the Job Details. Identified by the specific sub-job type code.

Failure to Commission (The Abort Process)

If a COMP-FULL status **IS NOT** achieved for the two job types specified above, you **CANNOT** leave the job "Pending." You must follow the **Abort Protocol**:

1. **Abort the Job:** Trigger a "Drop Elec" or "Drop Dual Fuel" status.
 - i. If no fail in over 60 minutes, will not have option to "Drop fuel."
2. **Clear Worksheets:** All worksheets must be emptied/cleared.
3. **Reinstall Old Meter(s):** All old metering must go back on the wall.
4. **Do Not Leave:** Under no circumstances should these be left as "Install & Leave" if commissioning fails.