From: Lowe, Claire (EGLE)
Sent: 1/30/2023 1:40:10 PM
To: "Shattuck, Terri (EGLE)" <ShattuckT@michigan.gov>
Subject: RE: Categorical determination - Cadillac casting - reply

Hi Terri,

Based on what they've told us I think all of the following would apply: 464.36(c)(1) for each of the two wet dust scrubbers, 464.36(f)(1) for each of the three melting furnace scrubbers, and 464.36.(h)(1) for the slag quench overflow. I'm still thinking about how the last one would work. I think it can be done just off the pounds limit if they know production for the day (if there is an overflow) and the total flow from the melting furnace WWTP. It should definitely be in the determination though.

I also agree that the compliance point for the 2 wet dust scrubbers would be the discharge from the North WWTP, and the melting furnace scrubbers, and slag quench (if it overflows) would be the melting furnace WWTP discharge.

Claire Lowe
Environmental Quality Analyst
Water Resources Division, Gaylord District Office
Michigan Department of Environment, Great Lakes, and Energy
989-330-4639|LoweC9@Michigan.gov
Michigan.gov/EGLE

EGLE | MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY

From: Shattuck, Terri (EGLE) <ShattuckT@michigan.gov>
Sent: Friday, January 27, 2023 5:46 PM
To: Lowe, Claire (EGLE) <LoweC9@michigan.gov>
Subject: RE: Categorical determination - Cadillac casting - reply

Thanks for the update.

For number 5, I think the slag quench subcategory will need to apply since they have overflow, but HOW that will work in the real world I'm not sure.
For number 6, I understand that the quench is a stage in the scrubber process. That is how I read that.
And number 7 it seems that since all three scrubbers are combined prior to entering the treatment system that there would be one compliance point for the series. My thinking is that the compliance point for pretreatment process water is after the treatment.

Let me know what you think.

From: Lowe, Claire (EGLE) <LoweC9@michigan.gov>
Sent: Friday, January 27, 2023 4:41 PM
To: Shattuck, Terri (EGLE) <ShattuckT@michigan.gov>
Subject: FW: Categorical determination - Cadillac casting - reply

Responses from Cadillac casting below. I also responded to the question under item 4. I'll keep on him about responding to that one.

Claire Lowe
Environmental Quality Analyst
Water Resources Division, Gaylord District Office
Michigan Department of Environment, Great Lakes, and Energy
989-330-4639 | LoweC9@Michigan.gov
Michigan.gov/EGLE

From: Erik Olson <eolson@cadillaccasting.com>
Sent: Friday, January 27, 2023 3:49 PM
To: Lowe, Claire (EGLE) <LoweC9@michigan.gov>
Cc: 'utilities@Cadillac-MI.net' <utilities@Cadillac-MI.net>; Patrick Miller <pmiller@cadillac-mi.net>
Subject: RE: Categorical determination - Cadillac casting - reply

CAUTION: This is an External email. Please send suspicious emails to abuse@michigan.gov

See below in red

From: Lowe, Claire (EGLE) <LoweC9@michigan.gov>
Sent: Friday, January 27, 2023 3:05 PM
To: Erik Olson <eolson@cadillaccasting.com>
Cc: utilities@cadillac-MI.net; Patrick Miller <pmiller@cadillac-mi.net>; Shattuck, Terri (EGLE) <ShattuckT@michigan.gov>
Subject: Categorical determination - Cadillac casting

Erik,

In follow up to our meeting last year, EGLE is completing a formal categorical determination for Cadillac Casting. To assist us with this process, please could you provide some additional information and clarifications listed below?

1. A description of the products produced by CCI.
   Ductile iron castings
2. Facility SIC code(s)
   3321
3. A list of any process chemicals used and associated SDS sheets. Included in this, does CCI use any penetrants or dyes as part of testing processes?
   We do not use any penetrants or dyes

4. A diagram and written description of the production processes. For guidance, please see the attached example of a production flow diagram.
   Will need to produce. What is the purpose relative to wastewater discharge? That diagram has been provided…
5. Please clarify if the slag quench process discharges any wastewater either to the treatment system or sanitary sewer.
   The wet slagger is recharged with fresh water as evaporation requires. <u>Under normal operating conditions, no water is discharged</u>. Overflow is possible and that water would be taken to our melt wwtp and go through treatment and be co-mingled with the melt scrubber waters.
6. Please confirm if the primary quench scrubber discussed during our meeting refers to a furnace scrubber, which is a quenching type scrubber, or if this refers to a scrubber used in a quenching process.
   This scrubber is scrubbing the exhaust air from our cupola iron melting furnace system. It is a quenching type scrubber stage.
7. The melting furnace scrubber includes a series of three scrubbers – does each scrubber produce a wastewater discharge?
   All three wastewater discharges lines meet and enter our wwtp system at the same location. The front section of our lamella clarifier called the flash mixer. It allow the flocculant polymer to be mixed ahead of the clarifier..

Thank you for your help with this. Please let me know if any of the above is unclear.

Claire Lowe
Environmental Quality Analyst
Water Resources Division, Gaylord District Office
Michigan Department of Environment, Great Lakes, and Energy
989-330-4639 | LoweC9@Michigan.gov
Michigan.gov/EGLE

EGLE | MICHIGAN DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY